

C-46



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/SZ/2025/ 569

Dated: 23/12/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Bloom Hotel (A Unit of Imperative Hospitality Pvt. Ltd located at E-586, Main Road, Greater Kailash -II, New Delhi-110048, comprised of Basement + Ground + 03 upper floors: Basement - Storage, Ground floor - Reception + 03 guest rooms + Dining area, 1st floor - 08 guest rooms, 2nd floor- 08 guest rooms, 3rd floor- 08 guest rooms, total 27 guest rooms was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/GH/2022/SZ/539 dated 14.12.2022. The premises was re-inspected by officer concerned of this department on 12.12.2025 in presence of Mr. Amit Kumar (Manager) and found that the Guest House has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of Group 'A (Residential) sub division A-1, with 27 guest rooms (Ground floor - Reception + 03 guest rooms + Dining area, 1st floor - 08 guest rooms, 2nd floor- 08 guest rooms, 3rd floor- 08 guest rooms) with effect from ..23.12.2025 and valid upto 31.03.2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on23/12/2025.....at New Delhi by


 (A. K. Malik)

Dy. Chief Fire Officer (SZ)

07/12/2025

Reference: elt.mcdonline application no. 2025112615168.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1	Name & address of the building	M/s Bloom Hotel (A Unit of Imperative Hospitality Pvt. Ltd located at E-586, Main Road, Greater Kailash -II, New Delhi-110048.		
2	Building is comprised of	Basement + Ground + 03 upper floors Basement - Storage Ground floor - Reception + 03 guest rooms + Dining area 1st floor - 08 guest rooms 2nd floor - 08 guest rooms 3rd floor - 08 guest rooms		
3	Type of occupancy	Residential Sub Division- A-1		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/GH/2022/SZ/539 dated 14.12.2022		
6	Fire safety directive letter no.	Nil		
7	Date of inspection	12.12.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (L.N)		
9	Name of the designation of officer From the building side	Mr. Amit Kumar (Manager)		
10	Year of construction	2004		
11	Applicant's letter no.	elt.mcdonline application no. 2025112615168		
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirement as per Rule 35 (6)	Provide at site	Remarks MR/NMR
1	Access to Building			
	A Road width	9.0 m	12. m	MR
	B Gate width	NA	NA	NA
	C Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	A No. of staircase:			
	a) Upper floor	Required (01) <u>2</u>	01 no.	MR (Old case)
	b) Basements	Required (02) <u>✓</u>	2 nos.	MR
	B Width of the staircase:			
	a) Upper floors	1.25 m	1.25 m	MR
	b) Basements	1.25 m	1.25 m, 1.0 m	MR (Old case)
	C Protection of exits (Required as per clause 7.31. x, UBBL 2016)			
	a) Fire check door	Required	Provided	MR
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace:	01 no.	01 no.	MR
	E Width of the corridor	NA	NA	NA
	F Door size	1.0 m	1.0 m (final exit)	MR
3	Compartmentation:			
	A Fire check doors	NA	NA	NA
	B Sealing of horizontal & vertical opening	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basements	Required	Exhaust fans	MR
	B Upper floors	Required	Exhaust fans	MR
5	Fire Extinguishers			
	A Total numbers	10 nos.	12 nos.	MR
	B Types	CO ₂ , ABC	CO ₂ , ABC	MR
	C ISI marking	Required	Provided	MR

21

6	First Aid Hose Reel				
	A	Total no. at each floor	1 no.	1 no.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS) (Required as per clause 7.31.viii, UBBL 2016).				
	A	Type of detectors	CO detector	Provided	MR
	B	Location of main Panel	At ground	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	NA	NA
	E	Hooter's location	Audible in entire building	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	NA	NA	NA
	B	No. of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of Standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	900 LPM	900 LPM	MR
		b) Head of terrace pump	30 m	30 m	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	6,000 ltrs	6,000 ltrs	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Fireman switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply		Required	Provided	MR

M/s Bloom Hotel (A Unit of Imperative Hospitality Pvt. Ltd located at F-55

-II, New Delhi-110048.

N/23

M/s Bloom Hotel (A Unit of Imperative Hospitality Pvt. Ltd located at E-586, Main Road, Greater Kailash -II, New Delhi-110048.


18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:			NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.


In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/2022/SZ/539 dated 14.12.2022 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

Last date 25/12/25


Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (L.N)


DO (SD)




15/12/25




A.K. MALIK


Principal Director

My. c/s to 
16/12/25


A.K. MALIK
DO (SD)

15/12/25