



No. F6/DFS/MS/School/NDZ/2025/ 686

Dated: 21/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Blue Bird Model Public School** located at **Kh. No.18/29, Ph IV, P-Block, 30 Ft. Road, Lok Vihar, Shiv Vihar, Delhi – 110094**, building comprised of Ground plus Two upper floors (School is running on ground & first floor only), owned/occupied by **Blue Bird Model Public School** was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2022/NDZ/469 dated 28/04/2022. The School building was re-inspected by the officer concerned of this department on 14/05/2025 in presence of Mr. Binod Kumar (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/ 3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B “**Educational Building**” with effect from 21/05/2025 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 21/05/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

e/Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Blue Bird Model Public School located at Kh. No.18/29, Ph IV, P-Block, 30 Ft. Road, Lok Vihar, Shiv Vihar, Delhi – 110094.

Conditions for the validity of Fire Safety Certificate

1. **This Fire Safety Certificate is valid for Ground floor and First floor only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Blue Bird Model Public School located at Kh. No.18/29, Ph IV, P-Block, 30 Ft. Road, Lok Vihar, Shiv Vihar, Delhi – 110094.		
2	Building is comprised of	Ground plus Two upper floors (School is running on ground & first floor only)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/School/2022/NDZ/469 dated 28/04/2022		
6	Fire safety directives letter no.	Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.		
7	Date of inspection	14/05/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Binod Kumar (Manager)		
10	Year of construction	2006-07		
11	Applicant's letter no.	Outdoor Diary No.1113 dated 28/05/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building:			
A	Road width	6.0 meters.	6.0 meters.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 no.	01 no	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.52 mtrs & 1.16 mtrs	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 nos.	01 nos.	MR
E	Width of corridor	1.50 meters	1.50 meters	MR
F	Door size	1.0 meter	1.10 meter	MR
3.	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

W
A

5. Fire Extinguisher:				
	A	Total numbers	06 nos.	06 nos.
	B	Types	CO ₂ & ABC	CO ₂ & ABC
	C	ISI marking	ISI Marked	ISI Marked
6 First-Aid-Hose Reel:				
	A	Total numbers of each floor	N/A	N/A
	B	Length of hose reel hose	N/A	N/A
	C	Nozzle diameter	N/A	N/A
7 Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A
	B	Location of main panel	N/A	N/A
	C	Location of repeater panel	N/A	N/A
	D	Alternate source of power	N/A	N/A
	E	Hooters	N/A	N/A
8 MOEFA:			N/A	N/A
9 Public Address System:			N/A	N/A
10 Automatic Sprinkler System:				
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A
11 Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A
	C	Hose box	N/A	N/A
12 Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A
	B	Hose box	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
	A	Discharge of main pump	N/A	N/A
	B	Head of main pump	N/A	N/A
	C	Number of main pumps	N/A	N/A
	D	Jockey pump out put	N/A	N/A
	E	Jockey pump head	N/A	N/A
	F	Standby pump out put	N/A	N/A
	G	Standby pump head	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A
	I	Pump house access	N/A	N/A
2 Terrace Level				
	A	Discharge of pump	N/A	N/A
	B	Head of the pump	N/A	N/A
	C	Power supply	N/A	N/A
	D	Auto starting of pump	N/A	N/A

(W)

N/17

Blue Bird Model Public School located at Kh. No. 18/29, Ph IV, P- Block, 30 ft. Road, Lok vihar Shiv Vihar Delhi - 110094.

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	N/A	N/A
15	Exit Signage:			
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			


The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2022/NDZ/469 dated 28/04/2022 Renewal under rule 35(6) of the Delhi Fire Rules 2010 is recommended.


15/5/2025

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO /Laxmi Nagar.

D.O/EAST


15/05/2025

Dy C.F.O. (NDZ)


15/05/25

C.F.O.


16/5/2025

Director



17/5/25



Sir, F.T. Letter is setup for sign. Please,

Director

20/5/25


19/5/2025