GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2025/ 270

Dated: 0.3./0.6./2025

To,

The Manager, Blue Pearl Guest House, 8653-8664, Arakashan Road, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Blue Pearl Guest House located at 8653-8664, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2025051108305 dated 11/05/2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 21/05/2025 in the presence of Manager and following shortcomings were observed:

- 1. Overhead tank capacity of 6600 liter is provided and water tank of 8400 liter found removed against the total required capacity of water 15,000 liter.
- 2. Further, fire check doors on the staircase are required to be provided as per health trade license issued by the MCD on dated 08.01.2024 for 39 room and 80 beds, whereas the FSC(fire safety certificate), was issued through online ID no. 2023081814835 dated 19.08.2023 for 39 room & 40 beds by this department as mentioned in the online application.

In view of above, the case is rejected and Fire Safety Certificate (FSC) issued vide letter no. 149 dated 12.09.2023 shall stand null and void. Therefore, you are requested to submit the compliance of above shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg) of ODIRECTOR

Delhi Fire Service

Copy to:- for information and n/a please.

1. The Commissioner, MCD, Civic Centre, New Delhi:

2. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.