

C-100

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/NZ/BNQT/2026/ 630

Dated: 07/07/2026

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

Sub:- Regarding renewal of Fire Safety Certificate in r/o M/s Mosaic Banquet (A Unit of Mosaic Hospitality) located at A 2, GF & FF, Wazirpur Industrial Area, Delhi - 110052.


Sir,

This has reference to MCD online application ID No. 2026060408035 dated 04.06.2026 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 18.06.2026 in presence of Mr. Chandan (Manager) and it was observed that banquet hall running at on ground plus two upper floors of the building which is comprised of Basement + ground + 02 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/MS/BQT/SZ/2025/11 dated 07.02.2025 except following which still exist:

1. The width of corridor/passage in entire path of travel should not be less than 1.50 m.
2. No lift lobby provided in basement.
3. Combustible material on terrace shall be removed.
4. The earlier FSC has been issued for assembly occupancy on ground & 1st floor but at the time of this inspection operational at all floor except basement. The management must forward the revised building plan with change in occupancy at 2nd floor through the local building sanctioning authority.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


4/7/26
(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
016 811 0417

Copy to:-

The Licensee,
M/s Mosaic Banquet (A Unit of Mosaic Hospitality) at A 2, GF & FF, Wazirpur Industrial Area,
Delhi - 110052.