

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2025/SZ/332
To

Dated: - 08 / 08 / 2025

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002

Sub: - Regarding issuance of fire safety certificate in r/o M/s Boka located at Ground Floor, 36, Community Centre, East of Kailash, New Delhi 110065

Sir,

This has reference to your **MCD Portal 2025071111257 dated 11/07/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.07.2025 in the presence of Mr. Gourav to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 There are two exit doors having width of 1.50 mtr & 1 mtr against the required width of 1.50 mtr each.
- 2 First aid hose reel hose found not working.
- 3 MOEFA not working.
- 4 Internal hydrant found not working.
- 5 Terrace level Fire Pump capacity of 450 LPM not working.
- 6 Overhead tank capacity 20,000 ltrs found removed.
- 7 Exit signage found removed.
- 8 Temporary Structure (PVC sheets) having nature of flammable has seen at the terrace of the restaurant, which is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


6/8/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

