

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/WZ/EH/07

Dated: 03/01/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Bomba Foods, Pvt. Ltd., 2LSC, located at Ground & Mezzanine floor, Block EFGH, Masjid Moth, Greater Kailesh-II, New Delhi 110048, in a building comprised of basement, mezzanine, ground + 07 upper floor, has already been issued FSC by this department vide letter No. F.6/DFS/MS/EH/SZ/2021/40 dated 23/02/2021 occupied by M/s LIT 2.0 Bar and Restaurant (A unit of Disney Hospitality India Pvt. Ltd.). The premises was re-inspected by the officer concerned of this department on 21.12.2024 in the presence of Mrs. Sandeep Anant, Manager and found that the said building have deemed complied with the fire prevention and fire safety requirements and that the premises fit for occupancy Class D 'Assembly Building' (restaurant running at Ground & Mezzanine floor only) with effect from 03/01/2025 valid up to 31.03.2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/01/2025 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000
02
my

Copy to: -

1. MCD Portal ID-2024113017510 dated 17.12.2024.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/29

INSPECTION REPORT

1. Name & address of the building	M/s Bomba Foods, Pvt. Ltd., 2LSC, Ground floor, Block EFGH, Masjid Moth, Greater Kailesh-II, New Delhi 110048. Previous name is M/s LIT 2.0 Bar and Restaurant (A unit of Disney Hospitality India Pvt. Ltd.)			
2. Type of Occupancy	Assembly Group-D			
3. Comprised of building	Basement, Ground, Mezzanine + 07 upper floors.			
4. Type of Case	Renewal (Restaurant running at Ground & Mezzanine Floor)			
5. Details of Previous NOC	F6/DFS/MS/EH/SZ/2021/40 dated 23/02/2021 Ground & Mezzanine Floor M/s LIT 2.0 Bar and Restaurant			
6. Fire Safety directives letter No	UBBL-2016/NBC Part-4			
7. Date of inspection	21.12.2024			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Mrs. Sandeep Anant, Manager			
10. Year of Construction	2006			
11. Applicant's letter No.	MHA Portal ID-2024113017510 dated 17.12.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35 (6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2nos	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.50m	1.50m&1.10m	MR(Old case)
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	02exit	Provided	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Exhaust Fan	-NA-
5.	Fire Extinguishers			
	a) Total numbers	06Nos	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR

A

6. First-Aid Hose Reels				
a) Total numbers on each floor	01nos.	Provided	MR	
b) Length of hose reel hose	30mm	Provided	MR	
c) Nozzle diameter	5m	Provided	MR	
7. Automatic fire detection and alarming system				
a) Type of detectors	-NA-	Provided	-NA-	
b) Location of Main Panel	-NA-	-NA-	-NA-	
c) Location of Repeater Panel	-NA-	-NA-	-NA-	
d) Alternate source of power	-NA-	-NA-	-NA-	
e) Hooters' Location	-NA-	-NA-	-NA-	
8. MOEFA	Required	Provided	MR	
9. Public Address System	-NA-	-NA-	-NA-	
10. Automatic Sprinkler System				
a) Basement	-NA-	-NA-	-NA-	
b) Ground & Upper Floors	Required	Provided	MR	
c) Sprinkler above false ceiling	-NA-	-NA-	-NA-	
11. Internal Hydrants				
a) Size of riser/down-comer	150mm	Provided	MR	
b) Number of hydrants per floor	01nos.	Provided	MR	
c) Hose Box	01nos.	Provided	MR	
12. Yard Hydrants				
a) Total number of hydrants	-NA-	-NA-	-NA-	
b) Hose Box	-NA-	-NA-	-NA-	
13. Pumping Arrangements				
• Ground Level				
➤ Discharge of main Pump	450LPM	Provided	MR	
➤ Head of Main pump	35m	Provided	MR	
➤ Number of main pumps	01	Provided	MR	
➤ Jockey Pump out put	225LPM	Provided	MR	
➤ Jockey pump head	35mtr	Provided	MR	
➤ Standby Pump out put	-NA-	-NA-	-NA-	
➤ Standby Pump Head	-NA-	-NA-	-NA-	
➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-	
➤ Pump House Access	-NA-	-NA-	-NA-	
Terrace level				
➤ Discharge of pump	-NA-	-NA-	-NA-	
➤ Head of the pump	-NA-	-NA-	-NA-	
➤ Power Supply	-NA-	-NA-	-NA-	
➤ Auto Starting of pump	-NA-	-NA-	-NA-	
14. Captive Water Storage for fire fighting				
• Underground tank capacity	50,000 ltrs	Provided	MR	
➤ Draw-off connection	-NA-	-NA-	-NA-	
➤ Fire service inlet	-NA-	-NA-	-NA-	
➤ Access to tank	-NA-	-NA-	-NA-	
• Overhead Tank capacity	5,000ltr	Provided	MR	
15. Exit Signage.	Required	Provided	MR	
16. Provision of Lifts.				
a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-	

N/31

MR	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
MR	c) Communication In lift Car	-NA-	-NA-	-NA-
MR	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
R	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/EH/SZ/2021/40 dated 23/02/2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (SD)

Mukherjee 30/12/24

Chakraborty
30/12/2024

Director
31/12/24

ADO(Rohini)

DO/SD *Mukherjee* 31/12/24

FT letter is put up
for kind perusal and
signature please.

Director

my upl...

Ajay
21/12/25
uploaded