



C-15

75  
आजादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2025/308

Dated: 25/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Bomba Pizzeria and Taqueria ( a Unit of Bomba food pvt. Ltd.), unit no. 21,22 & 23, Ground Floor, Khasra No. 251,252,253 & 254 Village Sulatanpur, Delhi 110030, in a building comprised of basement + ground plus + 02 upper floors. Owned/Occupied by M/s Bomba Pizzeria and Taqueria ( a Unit of Bomba food pvt. Ltd.), the building/premises was inspected by the officer concerned of this department on 11/08/2025 in the presence of Sh. Deepanshu Gupta and found that the said premises/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) (For restaurant at ground floor only) and validity upto 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on ..25/08/2025 at New Delhi by.

  
22/8/2025  
Virendra Singh  
Chief Fire Officer

Copy to: -

1. The owner/occupier, M/s Bomba Pizzeria and Taqueria ( a Unit of Bomba food pvt. Ltd.), unit no. 21, 22 & 23, ground floor, khasra No. 251,252,253 & 254, at Village Sulatanpur, Delhi 110030. Online Application ID No. 2025072711929 dated 27/07/2025

**Conditions for the Validity of Fire Safety Certificate:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the risk and responsibility of managements.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation, with regards to construction shall be verified by the concerned building sanctioning agencies.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments/directions of licensing department shall always be permitted and followed.
7. The means of escapes shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

N/B

### INSPECTION REPORT

1.	Name & address of the building	M/s Bomba Pizzeria and Taqueria ( a Unit of Bomba food pvt. Ltd.), unit no. 21,22 & 23, Ground Floor, Khasra No. 251,252,253 & 254 Village Sulatanpur, Delhi 110030.
2.	Type of Occupancy	Eating House /Assembly Occupancy
3.	Type of Case	New
4.	Details of previous NOC	Nil
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	11/08/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Deepanshu Gupta
9.	Year of Construction	2012 (As per MHA Portal)
10.	Applicant's letter No.	Online Application ID No. 2025072711929 dated 27/07/2025

The said restaurant is running at ground floor, in a building comprised of basement, ground and two upper floors.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per UBBL/ NBC part-IV	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 mtr	Provided	MR
		4.5m	On Main Road	MR
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	NA	At Ground floor	NA
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	NA	NA	NA
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NR	NR	NR
		NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NR	NR	NR
	g. Door Size	1.5m x 2	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	06 nos. CO <sub>2</sub> , ABC type ISI marked	Provided	MR
			Provided	MR
			Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

N/S

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked & found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is **recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.**

~~DO (South)~~

*[Signature]*  
14/8/25  
Signature of the Inspecting Officer  
Sarabjeet Singh ADO (MN)

*[Signature]*  
18/8/25

298/ADo/MN  
14/08/25

*[Signature]*  
18/8/2025

~~Principal Director~~

CFD to Genl.  
*[Signature]*  
19/08/25

*[Signature]*  
20/8/2025

~~DO (South)~~  
~~ADO (MN)~~

Sir, R.T is put up for your kind  
perusal & signature pls. *[Signature]*

*[Signature]*  
22/8/2025

*[Signature]*  
21/8/2025

MS

uplandeeet