



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-9



No:F.6/DFS/MS/2026/WZ/ 547

Dated: 04/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
S.P.M. Civic Centre, J.L. Nehru Marg
New Delhi 110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Ms Bounce N Giggles
(A Unit of Souleista Pvt. Ltd.) located at A-9, F.F., Shubham Enclave,
Paschim Vihar, Delhi- 110087.

Sir,

This has reference to online application received through MCD portal vide ID- 2026051606990 on the subject cited above. In this connection, it is to inform you that the above said assembly building was inspected by the officer concerned of this department on 25/05/2026 to see the compliance of requisite fire safety measures. Sh. Naresh was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. First aid hose reel found provided but not functional.
2. MOEFA found provided but not functional.
3. Internal hydrant found provided but not functional.
4. Terrace level pump not found in auto mode.
5. Exit signage's not provided.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

[Handwritten Signature]
02/06/26

S.K. Dua
Chief Fire Officer
Delhi Fire Service

[Handwritten Signature]

Copy to:-

1. Ms Bounce N Giggles (A Unit of Souleista Pvt. Ltd.) located at A-9, F.F., Shubham Enclave, Paschim Vihar, Delhi- 110087.
2. MCD Portal ID No. 2026051606990.