

21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 33

Dated:-21/01/2025

To,
The Manager
M/S Brims Coffee House, Shop No. HS-7,
Second Floor Kailash Colony, Main
Market, Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Brims Coffee House, Shop no. HS-7,
Second Floor Kailash Colony, Main Market, Delhi.**

Sir,
This has reference to online ID No. 2025010200057 dated 02/01/25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 11/01/25 in the presence of Mr. Khalid and following shortcomings were observed:-

1. Alternate exit of 1.35 m is provided against the requirements of 1.5 meter.
2. Pumps, hose reel found nonfunctional and hydrant is also not provided at second floor.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Joint commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.