



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव


No. F6/DFS/MS/WZ/School/2025/WZ/ 732

Dated:- 06/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Brilliant Convent Sr. Sec. School, located at West Enclave, Pitampura, Delhi- 110034, comprised of Ground + 03 Upper Floors only, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2022/508 dated 12/05/2022. The said premise was re-inspected by the officer concerned of this department on 27/05/2025 in the presence of Sh. Dilbag Singh Mann (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 06/06/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 06/06/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Brilliant Convent Sr. Sec. School, West Enclave, Pitampura, Delhi-110034.

Conditions for the validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building : Brilliant Convent Sr. Sec. School, located at West Enclave, Pitampura, Delhi-110034
2. Type of Occupancy : Educational (Ground + 03 Upper Floors only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/508 dated 12/05/2022
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17/01/2005 & directive issued vide letter no. F.6/DFS/MS/BP/2023/314 dated 15/10/2013 for 3rd floor
6. Date of inspection : 27/05/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Dilbag Singh Mann (Manager)
9. Year of Construction : 2002-03
10. Applicant's letter No. : email dated 17/04/2025

10. Applicant's letter no.

S No	Minimum standards on fire prevention and fire safety U/R 33	As per requirement D.O.E. Cr. No. 262-362 dated 17/01/2005/ as per earlier FSC issued dated 12/05/2022	Provided at site	Remarks MR/NMR									
1.	Access of building			MR									
	<ul style="list-style-type: none">Road widthGate widthWidth of internal road	<table><tr><td>Accessible</td><td>09 m</td><td>MR</td></tr><tr><td>Accessible</td><td>3.63 m</td><td>MR (Old Case)</td></tr><tr><td>NA</td><td>NA</td><td>NA</td></tr></table>	Accessible	09 m	MR	Accessible	3.63 m	MR (Old Case)	NA	NA	NA		
Accessible	09 m	MR											
Accessible	3.63 m	MR (Old Case)											
NA	NA	NA											
2.	Number, width, Type & Arrangements of exits												
	a. Number of staircases	02	Provided	MR									
	<ul style="list-style-type: none">Upper floorsBasements	NA	NA	NA									
	b. Width of staircases	1.5 m	1.32 m x 1 & 1.36 m x 1	MR (Old Case)									
	<ul style="list-style-type: none">Upper floorsBasements	NA	NA	NA									
	c. Protection of exits	NA	NA	NA									
	<ul style="list-style-type: none">Fire check doorPressurization	NA	NA	NA									
	d. No of continuous staircase to terrace	01	Provided	MR									
	e. Width Of Corridor	1.5 m	1.48 m	MR (Old Case)									
	f. Door Size	1.0 m	1.13 m	MR									
3.	Compartmentation												
	<ul style="list-style-type: none">Fire check doorSealing of electrical shaftsFire Rating of shaft doorWater CurtainFire Dampers	NA	NA	NA									
		NA	NA	NA									
		NA	NA	NA									
		NA	NA	NA									
		NA	NA	NA									
4.	Smoke managements System												
	<ul style="list-style-type: none">BasementsUpper floors	NA	NA	NA									
		NA	NA	NA									

5.	Fire Extinguishers			
	• Total numbers	27 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reel			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- During inspection, a small basement found in the building having 27.4 x 5.96 m² with 02 nos. exit door 1.5 m each. Basement is not used for school activity.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as per D.O.E. Circular no. 262-362 dated 17/01/2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2022/508 dated 12/05/2022 is recommended.

Accordingly, DFA is prepared for approval & signature please.

DeFO (WZ)

Aman Kumar Lathar
ADO (JWP)

dy
29/5/2025

CFO
30/5/2025

5.10.2024
22/5/2025

Dy CFO (WZ)

dy
26

ADO (JWP)

Sir, F.S. letter is put-up for your signature pl.

CFO
31/6/2025

Aman Kumar Lathar
ADO (JWP)

m c cell