

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2025/BP/ 247

Dated: 03/06/2025

To,

The Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road
New Delhi 110002.

Subject: Regarding clearance of building plans from fire safety point of view in r/o Building No. 26 Sports and Cultural Activities IHMMR and IIS Jamia Hamdard, New Delhi.

Sir,

Please refer your ID No. 10120444 dated 20.05.2025 on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed:

1. The occupancy mentioned in CAF is not matching with buildings, same shall be clarified in terms of clause 1.4.75 of UBBL 2016.
2. The width of staircases are not proposed as per clause 7.11.1 of UBBL 2016.
3. Kitchen area is not separated as per clause 3.1.11 of NBC Part 4

Accordingly the case cannot be examined and therefore rejected.

Yours faithfully


3/6/2025
(Virendra Singh)
Chief Fire Officer
011 23412225

CS