



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/NDZ/2026/ **357**

Dated: - **23/04/2026**

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110001

Sub: Regarding renewal of FSC in r/o M/s Bunon Bar & Lounge (A Unit of AVS Hospitality), 1st Floor, R. K. Ashram Metro Station, DMRC Bharat Nagar, Paharganj, New Delhi - 110055.

Sir,

Please refer to online application No. 2026032303421 dated 24/03/2026, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officers concerned of this department on 09/04/2026 in the presence of **Mr. Gurfan, Manager** and following shortcomings were observed: -

1. Smoke Management System not provided.
2. First-aid Hose reel found damaged.
3. Jockey pump provided but found non-functional.
4. Automatic operation of Fire Pumps found non-functional.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,


22/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

012 B89

Copy to: -

1. The Manager, M/s Bunon Bar & Lounge (A Unit of AVS Hospitality), 1st Floor, R. K. Ashram Metro Station, DMRC Bharat Nagar, Paharganj, New Delhi - 110055.