

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No.F6/DFS/MS/2025/Hospital/140

Dated 02/04/2025

To.

Dr. Aseem Taneja (OSD)
Burari Hospital Govt. of NCT of Delhi.
Kaushik Encalve, Burari, Delhi-110084.

Sub:- Renewal of fire safety certificate in r/o Burari Hospital located at Kaushik Enclave, Burari, Delhi-110084.

Sir,

This has reference to your letter received through online e-mail dated: 06.03.2025 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 26.03.2025 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Kuldeep Sharma (AE. Elec.), along with other members of PWD was also present at site. During the course of the inspection it is observed that the building is comprised of two level basement, ground & 07 upper floors. Your request for FSC is rejected under Rule 37 due to following shortcomings:-

1. Some fire check doors & door closer found damaged condition.

2. Smoke management system in basement not proper functional and some ducting found damaged/leakage condition.

3. Staircases No.5 & No.10 pressurization is provided but not functional.

Keeping in view of above shortcomings, the said building is not safe from fire safety point of view & renewal of Fire Safety Certificate cannot be considered at this stage. Hence, you are advised to comply all the shortcomings at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non- compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

tul Garg)
Director

Ph.-011-25104000

Copy to:-

1. Sh. Mohd. Ikbal, AE (E), Dr. Baba Sahab Ambedkar Hospital, Sector-6, Rohini, Delhi-85.