



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/EH/2026/NDZ/ 349

Dated: 13/04/2026

FIRE SAFETY CERTIFICATE

Certified that the **M/s Burger King India Limited** located at Shop No. G 3A, Ground Floor, Dilshad Garden Metro Station, Delhi-110095 of the building comprised of ground plus one upper floor but restaurant is running at Ground floor only owned/occupied by **M/s Burger King India Restaurant** was issued FSC vide letter No. F.6/DFS/MS/EH/NDZ/2023/203 dated 27/06/2023. The premises was re-inspected by the officer concerned of this department on dated 23/03/2026 in the presence of Manager and observed that all the fire prevention and fire safety arrangements provided in the premises and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit occupancy class "**Assembly**" **Group D (Ground Floor only)** with effect from 13/04/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions Mentioned Below.

Issued on 13/04/2026 at New Delhi by.


13/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above
 2. Sh. Deepak Yadav, M/s Burger King India Restaurant at Shop No. G 3A, Ground Floor, Dilshad Garden Metro Station, Delhi-110095
- MCD ID No. 2026030302307**

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/Jo.

1. Name & address of the building : **Burger King India Limited**
Shop No. G 3A, Ground Floor, Dilshad Garden Metro Station, Delhi-95
2. Building is comprised of : Ground Plus one upper floor
(Restaurant at Ground Floor only)
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/NDZ/2023/203 dated 27/06/2023
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 23/03/2026
8. Name of the Inspecting officers : Deepak Kumar ADO(Shd./TP)
9. Name and designation of Officer
from the building side : Manager
10. Year of Construction : 2010
11. Applicant's letter No : 2026030302307 dated- 03/03/2026

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			MR
	• Road width	06 mtr.	18 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			N/A
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			N/A
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
	g. No. Of Doors	02 nos.	02 nos.	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

2.

06	First-Aid-Hose Reels.	Common with Metro Station		
	Total numbers	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	Smoke/Heat	N/A
	• Location of main panel	N/A	Provided	N/A
	• Location of repeater panel	N/A	Provided	N/A
	• Alternate source of power	N/A	Provided	N/A
	• Hooter	N/A	Provided	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Common with Metro Station		
	• Discharge of main pump	1800 lpm	1800 lpm	MR
	• Head of main pump	70 mtrs	70 mtrs	MR
	• Number of main pumps	02 nos	02 nos	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	70 mtr	70 mtr	MR
	• Standby pump out put	1800 lpm	1800 lpm	MR
	• Standby pump head	70 mtr	70 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting	Common with Metro Station		
	• Underground tank capacity	50,000 ltrs	2,00,000 ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:			

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules. The FSC issued vide letter No. F.6/DFS/MS/EH/NDZ/2023/203 dated 27/06/2023 renewal under rule 37 of the Delhi Fire Service Rule, 2010 is recommended.

Last Date:- 01/04/2026

Deepak
24/03/2026.
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Tahirpur)

DO (ED)

- Pl. check FSC of Metro station.

- Earlier the building is B+G+30F. now B+G+20F.

Pl. clarify.

Mukherjee

ADO (P)

Sir,
(1) FSC already issued of DMRC Dilshad Garden Metro station

Vide letter No. F.6/DFS/MS/DMRC/NDZ/2024/445 dated 12/07/2024.

(2) Building is comprised of Ground, concourse level (Platform floor) and Platform level (Terrace floor). Wrongly mentioned in the previous FSC.

Re-Submitted for your kind approval pl.

Deepak
27/03/2026.