

c/05

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No. F6/DFS/MS/EH/NDZ/2025/ 184

Dated: 30/04/2025

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

Sub: Regarding renewal of fire safety certificate in respect of Burrito Restaurants Pvt. Ltd., located at 1-C, Ground Floor, Opp. Green Park Extn, Hauz khas, Delhi-110029.

Sir,

Please refer to your online application no. 2025040405631 dated 05/04/2025, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 23/04/2025 in the presence of Sh. Amit Chauhan to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor only in a building comprised of Basement + Ground + 02 Upper Floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. There are two exits door 1 X 1.05m & 1 X 1.0m against the required of 1.50 mtr each.
2. Smoke Management System are not provided.
3. First Aid Hose reels are provided but not functional.
4. Internal Hydrants are provided but not functional.
5. 900 LPM pump provided but not functional.
6. Overhead water storage tank of 5,000 ltrs is provided against requirement of 20,000 ltrs.
7. Exit signage are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, South Zone, Green Park, Delhi-110016.
2. The Owner/Occupier, Burrito Restaurants Pvt. Ltd., located at 1-C, Ground Floor, Opp. Green Park Extn, Hauz khas, Delhi-110029.