



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2026/WZ/Restaurant/ 522

Dated: 03/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Burrito Restaurant Pvt. Ltd. located at Shop No.-2B, Ground floor, Shalimar Bagh Metro Station, Delhi-110088, comprised of Property Development Area ground floor and M/s Burrito Restaurant Pvt. Ltd restaurant is running at Shop No.-2B, Ground floor in a Metro Station was inspected by the officers concerned of this department on 25.05.2026 in the presence of Mr. Sujan Sunwar (Store Manager), and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class Assembly for Restaurant running at Shop No.-2B, Ground floor only with effect from 03/06/2026 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/06/2026 at New Delhi by


(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Center, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: MCD Portal Id-2026051306771 dated 13.05.2026.
2. The Authorized Signatory, M/s Burrito Restaurant Pvt. Ltd. located at Shop No.-2B, Ground floor, Shalimar Bagh Metro Station, Delhi-110088.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on .
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+a+nd+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/18

N-5

INSPECTION REPORT

1. Name & address of the building	M/s Burrito Restaurant Pvt. Ltd. located at Shop No.-2B, Ground floor, Shalimar Bagh Metro Station, Delhi-110088.
2. Type of Occupancy	Assembly Building
3. Comprised of building	Property Development Area ground floor
4. Type of Case	New Case (Burrito Restaurant is running in Shop No.-2B, Ground floor)
5. Details of Previous NOC	NBC Part-IV
6. Fire Safety directives letter No	N/A
7. Date of inspection	25.05.2026
8. Name of Inspecting Officer	Ajay Kumar Sharma ADO (Wazirpur)
9. Name and designation of officers From the building side	Mr. Sujan Sunwar (Store Manager)
10. Year of Construction	2022 on MCD Portal
11. Applicant's letter No.	Online application No.2026051306771 dated 13.05.2026.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building (PD Area Shalimar Bagh Metro Station issued FSC No.F.6/DFS/MS/2026/WZ/31 dated 25.02.2026)			
	- Road width - Gate width - Width of internal road	Restaurant within Metro station	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Metro Station]			
	a. Number of staircases			
	- Upper Floors - Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	- Upper Floor - Basements	-NA-	-NA-	-NA-
	c. Protection of exits	[Provided & Maintained by Metro Station]		
	- Fire check door - Pressurization	Required in kitchen	Provided	MR
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	2 x 1.5m	Provided	MR
3.	Compartmentation			
	a) Fire check door	Required in kitchen	Provided	MR
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	Restaurant within Metro station	As Above	MR
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System	[Provided & Maintained by Metro Station]		
	c) Basements	-NA-	-NA-	-NA-
	d) Upper floors	Mechanical/Natural ventilation	Natural	MR
5.	Fire Extinguishers			
	a) Total numbers	04nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reel	[Provided & Maintained by Metro Station]		

	d) Total numbers on each floor	Near to restaurant	Provided	MR
	e) Length of hose reel hose	30mm	Provided	MR
	f) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Metro Station]			
	a) Type of detectors	-NA-	Provided	MR
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System [Provided & Maintained by Metro Station]			
	a) Basement	-NA-	Provided by Metro Station	-NA-
	b) Ground & Upper Floors	-NA-	Provided by Metro Station	-NA-
	c) Sprinkler above false ceiling	-NA-	Provided by Metro Station	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	Provided by Metro Station	-NA-
	b) Number of hydrants per floor	-NA-	Provided by Metro Station	-NA-
	c) Hose Box	-NA-	Provided by Metro Station	-NA-
12.	Yard Hydrants [Provided & Maintained by Metro station]			
	a) Total number of hydrants	-NA-	Provided by Metro Station	-NA-
	b) Hose Box	-NA-	Provided by Metro Station	-NA-
13.	Pumping Arrangements [Provided & Maintained by Metro station]			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	2850lpm	-NA-
	➤ Head of Main pump	-NA-	90m	-NA-
	➤ Number of main pumps	-NA-	02nos.	-NA-
	➤ Jockey Pump out put	-NA-	2 x 180lpm	-NA-
	➤ Jockey pump head	-NA-	56m	-NA-
	➤ Standby Pump out put	-NA-	2850lpm	-NA-
	➤ Standby Pump Head	-NA-	90m	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting [Provided & Maintained by Metro Station]			
	• Underground tank capacity	NA	2,00,000ltr	MR
	➤ Draw-off connection	NA	Provided by Metro station	MR
	➤ Fire service inlet	NA	Provided by Metro station	MR
	➤ Access to tank	NA	Provided by Metro station	MR

N/20

N-7

	Overhead Tank capacity	10,000ltr	2,00,000 Ltrs provided by metro	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	[Provided & Maintained by Metro Station]		
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.	[Provided & Maintained by Metro Station]		
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 670 dated 24.04.2026, under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010

Signature of the Inspecting Officer

[Signature]
25/5/26

Name: - Ajay Kumar Sharma
Designation:- ADO (Wazirpur)

DO (West)

[Signature]
26/5

[Signature]
CFO/WZ

[Signature]
Pr. Director

[Signature]
27/05/26

CFO to Secy.
[Signature]
27/05/26

[Signature]
CFO (WZ)

F.T. please.

[Signature]
27/05/26
F.P. wine
ADW (P)

FT letter to pur
up for kind please
[Signature]
29/05/26