

C49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2025/ 982

Dated: 11/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **B.V.M. Model (Sr. Sec.) School, Rajiv Nagar, Begumpur, Opp. Sec-22, Rohini, Delhi-110086**, comprised of **Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2022/518** dated **12.05.2022**. The premises was re-inspected by the officer concerned of this department on **27.07.2025** in the presence of **Mrs. Kanta Sharma (Principal)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 11/08/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/08/2025 at New Delhi by


8/8/2025
(Virendra Singh)
Chief Fire Officer

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, B.V.M. Model (Sr. Sec.) School, Rajiv Nagar, Begumpur, Opp. Sec-22, Rohini, Delhi-110086.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : B.V.M. Model (Sr. Sec.) School, Rajiv Nagar, Begumpur, Opp. Sector-22, Rohini Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : **Renewal (Ground + 03 upper floors)**
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2015/1694 dated 07.05.2015)
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 27.07.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Kanta Sharma (Principal)
9. Year of Construction : 2013, 2016 & 2019
10. Applicant's letter No. : Online e-mail dated 05.05.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible Accessible -NA-	Accessible Provided -NA-	MR (Old case) MR (Old case) -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02nos.	03nos.	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	-NA-	-NA-	-NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5m -NA-	1.8, 1.5 & 1.25m -NA-	MR -NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	02nos.	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	-NA- 12 a/c per hour	-NA- Natural ventilation	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	15nos. ABC/CO2 ISI marked	15nos. ABC-15 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01nos. 30mm 5m	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-

N/25

A Loc
Fig

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 lpm	2 x 450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000ltr	2 x 5000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total Area 			

	Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2022/518** dated **12.05.2022** is **recommended** for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
29/7/25

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

[Signature]
30/07/2025

by cfo (ms)

[Signature]
30/7/2025

[Signature]
4/8/2025

Principal Director

CFO + Secy.

[Signature]
05/08/25

ADO(Rohini)

FT letter is put up for (Cand)
perusal and signature please.

[Signature]
7/8/25

CFO *[Signature]*
8/8/2025

MS

DCFO/351-N/25
Dated 30/07/25