



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/2026/816

Dated: 27/08/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in respect of M/s. Haldiram Marketing Pvt Ltd, located at C-197 Jawahar Park, Village Khanpur, Tehsil Hauz Khas, Main Khanpur, Devli Road, New Delhi-110062.


Sir,

Please refer to your online application ID No. 2026071309748 dated-13/07/2026, on the subject cited above. In this connection, it is to inform you that the premise was inspected by officer concerned of this department on 27/07/2026 in the presence of Sh. Jitender (Manager) to see the functioning of fire safety arrangements/equipments provided in the building. During inspection the following shortcomings were observed.

1. Staircases & Door sizes both of width 1.50m are provided against requirement of 2m and 1.5m.
2. Main Fire Pump capacity of 900LPM is provided but not on auto-mode.
3. Exit signage's not provided.

In view of above, the application for issuance of Fire safety Certificate is cannot consider at this stage.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s. Haldiram Marketing Pvt Ltd, located at C-197 Jawahar Park, Village Khanpur, Tehsil Hauz Khas, Main Khanpur, Devli Road, New Delhi-110062. (Online application No. 2026071309748 dated-13/07/2026).