



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

CL27



No: F.6/DFS/MS/2025/WZ/ 456

Dated: 15/03/2025

To,

Sh. Rajeshwar Garg,
Narsingh Dass Jan Sewa Samiti,
Community Hall Building,
K(P) Block, Pitampura, Delhi- 110088.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Community Hall Building
Located at K(P) Block, Pitampura, Delhi- 110088.

Sir,


This has reference to your J dated 18/08/2025 received through outdoor diary no. 4990 dated 19/08/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said assembly building has been carried out by officer concerned of this department on 29.08.2025 to see the compliance of the requisite fire safety measures. Sh. Sanjeev Mishra (Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground plus two upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional.
2. Internal hydrants found provided but not functional.
3. Terrace level pump found provided but not functional.
4. Overhead tank found removed.
5. Exit signage's found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully


(Virendra Singh)
Chief Fire Officer
