

256

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/GH/2025/ 125

Dated: 19/03/2025

To,

Mr. Devender Kumar Gupta,
House No.A-B29,
Mianwali Nagar, Rohtak Road,
New Delhi-110087.

Sub: Renewal of FSC in r/o M/s C Pearls Hotel (A class Hospitality LLP) located at Khasra No.523/1.527/1.528/1 2nd floor, Village, Mundaka, Rohtak Road, Delhi-110041.

Sir,

This is reference to online application no.2025021702003 dated 27.02.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **10.03.2025**, in presence of **Mr. Dupinder (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD found removed in staircase.
2. Smoke management /ventilation found removed in upper floors.
3. Hose & branch are not provided in hose boxes.
4. CO detector system found removed.
5. Terrace fire pumps were not found in auto mode.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Gang)
DIRECTOR
Ph: 011-23414000

Copy To:-

1. MCD Portal Id- 2025021702003 dated 27.02.2025.