

## FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F 6/DFS/MS/2026/EH/WZ/ 67

Dated: 23/01/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Café After Hours (A unit of La Logos Sante Hospitality Pvt. Ltd.) Located at Plot no. 1, BG-1 & BG-2, Paschim Puri, New Delhi- 110063 is running at FF-1, FF-2, FF-2A, SF-1, SF-1B, SF-1C EMaya Mall (Gourmet Hub) in a building comprised of Basement, Ground plus three upper floors was issued FSC by this department vide letter No F6/DFS/MS/EH/WZ/2023/10 dated 09.01.2023. The premise was re-inspected by the officer concerned of this department on 13.01.2026 in the presence of Mr. Mahesh (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy class "Assembly" (Group D) for Restaurant at shop No. FF-1, FF-2, FF-2A, SF-1, SF-1B, SF-1C only with effect from ....23/01/2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ....23/01/2026.. at New Delhi, by


  
 (S.K. Dua)

**Dy. Chief Fire Officer**  
**West Zone**

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi- to ensure the occupancy as detailed above. (Ref- MCD Portal, ID No. 2026010100012).
2. M/s Café After Hours (A unit of La Logos Sante Hospitality Pvt. Ltd.) FF-1, FF-2, FF-2A, SF-1, SF-1B, SF-1C EMaya Mall (Gourmet Hub) Located at Plot no. 1, BG-1 & BG-2, Paschim Puri, New Delhi- 110063.

**Conditions for the validity of Fire Safety Certificate:**

1. This FSC is valid for the Restaurant at Shop No. FF-1, FF-2, FF-2A, SF-1, SF-1B, SF-1C only.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.nic.in>) along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : M/s Café After Hours (A unit of La Logos Sante Hospitality Pvt. Ltd.), Running at FF-1, FF-2, FF-2A, SF-1, SF-1B, SF-1C EMaya Mall (Gourmet Hub), Located at Plot no. 1, BG-1 & BG-2, Paschim Puri, New Delhi- 110063.

2. Type of Occupancy : Class-D (Assembly)

3. Building Comprised of : Basement, Ground plus Three upper floors

4. Type of Case : Renewal

5. Details of Previous NOC : F6/DFS/MS/EH/WZ/2023/10 Dated- 09/01/2023

6. Fire Safety directives letter No : N/A

7. Date of inspection : 13/01/2026

8. Name of Inspecting Officer : R.K.Sinha, ADO (Jawala Puri)

9. Name and designation of officers  
From the building side : Mr. Mahesh (Manager)

10. Year of Construction : 2013 as per MCD Portal.

11. Applicant's letter No. : MCD Application ID No. 2026010100012 dated 01/01/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated – 23/12/2022	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	Road width	12 m	30m	MR
	Gate width	06 m	Provided	MR
	Width of internal road	06 m	Provided	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	Number of staircases			
	Upper Floors	02	Provided (04)	MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	1.5 m each	Provided	MR
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	Required	Provided	MR
	Width of Corridor	1.5 m	Provided	MR
	Door Size	2.0, 1.35 m	Provided	MR
3.	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	Basements	NA	NA	NA
	Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	Total numbers	06 Nos.	Provided	MR
	Types	ABC/Co2 Type	ABC/ Co2	MR
	IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>	(Provided by Mall )		
	Type of detectors	Smoke	Provided	MR
	Location of Main Panel	Ground floor	Provided	MR
	Location of Repeater Panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters' Location	Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA

10.	<b>Automatic Sprinkler System</b>		<b>(Provided by Mall)</b>	
	Basement	NA	NA	NA
	Upper Floor	Required	Provided	MR
	Sprinkler above false ceiling	Required	Provided	MR
11.	<b>Internal Hydrants</b>		<b>(Provided by Mall)</b>	
	Size of riser/down-comer	150 mm	Provided	MR
	Number of hydrants per floor	04	Provided	MR
	Hose Box	04	Provided	MR
12.	<b>Yard Hydrants</b>		<b>(Provided by Mall)</b>	
	Total number of hydrants	Required	Provided	MR
	Hose Box	Required	Provided	MR
13.	<b>Pumping Arrangements : Wet Riser cum Down Comer System Provided in place of Down Comer</b>			
	Ground Level			
	Discharge of main Pump	NA	2280 lpm	NA
	Head of Main pump	NA	70 m	NA
	Number of main pumps	NA	01	NA
	Jockey Pump out put	NA	180 lpm	NA
	Jockey pump head	NA	70 m	NA
	Standby Pump out put	NA	2280 lpm	NA
	Standby Pump Head	NA	70 m	NA
	Auto Starting/Manual Stopping	NA	Provided	NA
	Pump House Access	NA	Provided	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply			
	Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for firefighting</b>		<b>(Provided by Mall)</b>	
	Underground tank capacity	NA	50,000 ltrs Provided	MR
	Draw-off connection	NA	Provided	MR
	Fire service inlet	NA	Provided	MR
	Access to tank	NA	Provided	MR
	Overhead Tank capacity	Required	Provided	MR
15.	<b>Exit Signage.</b>		<b>Required</b>	
16.	<b>Provision of Lifts.</b>		<b>(Provided by Mall)</b>	
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>		<b>NA</b>	
18.	<b>Refuge Area.</b>			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	<b>Fire Control Room</b>		<b>(Provided by Mall)</b>	
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA

NA  
RSpecial Fire Protection System for  
Protection of special Risks, if any:

NA

NA

NA

N-15

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is **recommended to renew** the Fire Safety Certificate issued vide letter number F6/DFS/MS/EH/WZ/2023/10 dated 09/01/2023 under rule 37 of Delhi Fire Service Rules, 2010.

DEEMED APPROVED AFTER 30/01/2026

*Ado  
Ado(JWP)  
14/1/2026*

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/Jawala Puri.

~~Do (Wst)~~ *14/1*

~~Dy CFO/CS~~

~~Fr. Director~~

~~Mr. CFO (NA)~~

~~ADO (JWP)~~

*LIV  
15/01/26*

~~Dy. CFO *Deputy*~~  
*15/01/26*

*F.T. please.*

*LIV  
16/01/26*

~~Dy CFO (CS)~~  
*F.P. wing*  
*Unloaded*

*LIV  
21/01/26*

*Ado  
Ado (JWP)  
20/1/2026*