



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/EH/ 137

Dated: 17/04/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Cafeteria & Co (A Unit of Jumbo Restaurants Pvt. Ltd.) located at G-14, 1st, 2nd & 3rd floor, Vijay Nagar, Delhi-110009, comprised of ground + 03 upper floors but Restaurant is running at 1st, 2nd & 3rd floor only has already been issued FSC by this department vide letter No. F.6/DFS/MS/EH/WZ/133 dated 20.05.2022. The premises was re-inspected by the officer concerned of this department on 05.04.2025 in the presence of Mr. Akhil Malik and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class 'D' (Assembly) with effect from 17/04/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/04/2025 at New Delhi by

(Atul Garg)
DIRECTOR

Ph: 011-23414000

Copy to: -

1. MCD Portal ID-2025031903951 dated 19.03.2025.
2. The Joint Commissioner of Police (Lic.) 1st floor, Licensing unit, Police Station, Defence Colony, New Delhi-

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/s Cafeteria & Co (A Unit of Jumbo Restaurants Pvt. Ltd.) located at G-14, 1 st , 2 nd & 3 rd floor, Vijay Nagar, Delhi-110009.
2. Type of Occupancy	Mixed occupancy-(assembly /Mercantile)
3. Comprised of building	Ground + 03 upper floors.
4. Type of Case	Renewal (Restaurant is running at 1 st , 2 nd & 3 rd floor only) 1 st floor- Restaurant Hall 2 nd floor- Restaurant Hall 3 rd floor-Kitchen
5. Details of Previous NOC	F.6/DFS/MS/EH/WZ/133 dated 20.05.2022.
6. Fire Safety directives letter No	-NA-
7. Date of inspection	05.04.2025
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
9. Name and designation of officers	Mr. Akhil Malik
2. From the building side	
10. Year of Construction	2014 On MCD Portal
11. Applicant's letter No.	Online application No. 2025031903951 dated 19.03.2025.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0m	12m approx	MR
	• Gate width	4.5m	Directly accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.25m & 1.5m	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	2.0m & 1.5	Provided	MR
3.	Compartmentation			
	a) Fire check door	Required to segregate kitchen and staircase at 3 rd floor	Provided	MR
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	08nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR

6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	Smoke	Provided	MR
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	Required	Provided	MR
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	a) Basement	-NA-	Provided	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01nos.	Provided	MR
	c) Hose Box	01nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	1620lpm	Provided	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01nos.	Provided	MR
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	1620lpm	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	50,000ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000ltr	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-

N/27

	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Rule 35 (6), and removal of shortcomings issued vide letter no. 74 dated 13.02.2025, the FSC issued vide letter no. F.6/DFS/MS/EH/WZ/133 dated 20.05.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

DCFO/..603-MHA

Dated..11.04.25

11/04/2025

By Cfo (WZ)

11/4

Cfo/ 15/4/2025

Director/ 15/4/25

AOO/

PT letter is put up to kind person and Signature please.