

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2025/SZ/440
To

Dated 03/09/2025

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002
Email ID commissioner@mcd.nic.in

Sub: -Regarding issuance of fire safety certificate in r/o M/s Call Chotu (A Unit of Paschion Restaurant Pvt Ltd) at HS 23, First Floor, Kailash colony Market, Kailash Colony, New Delhi 110048.


Sir,

This has reference to with **MCD Portal 2025040505696 dated 06/08/2025** on the subject cited above. In this connection, this is to inform you that the above-mentioned premise was visited by the officer concerned of this department on 22.08.2025 in the presence of Md. Bilal to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. Only single staircase is available for visitors. The access to second staircase is through occupied kitchen. The both of the staircases shall be remote form each other.
2. Manual Operated Electrical Fire Alarm (MOEFA) system not provided.
3. Internal hydrant not provided.
4. Terrace tank capacity 10,000 ltrs provided against the requirement of 20,000 ltrs.
5. Exit Signages not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


31/9/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

