



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2025/ 39

Dated: 17/01/2025

To

The Principal,
Cambridge Public School,
C-2, Sangam Vihar, New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Cambridge Public School** located at **C-2, Sangam Vihar, New Delhi.**

Sir,

With reference to the letter bearing outdoor diary no. 10704 dated 24.12.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 08.01.2025 in the presence of Mr. R.K. Sharma (Admin.) and following shortcomings were observed during the inspection.

1. Hose reel found non functional.
2. Automatic sprinkler system found non functional.
3. Fire pump found non functional.
4. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, GNCT of Delhi, Old Secretariat, New Dehli-54.

15/1/25. C