



C-55



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

Dated: 18/02/2025

No. F.6/DFS/MS/School/2025/NDZ/170

FIRE SAFETY CERTIFICATE

Certified that the Canterbury Model Public School located at B-46/10A, Main Wazirabad Road Bhajanpura, Delhi-110053, comprised of ground plus three upper floors (Porta cabin sealed) owned/occupied by Canterbury Model Public School was issued FSC vide letter No. F.6/DFS/MS/School/2021/NDZ/1096 dated 31/12/2021. The premises was re-inspected the officer concerned of this department on 13/02/2025 in the presence of Sh. Neeraj Gupta (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from ...18/02/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on.....18/02/2025..... at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

The Principal,
Canterbury Model Public School,
B-46/10A, Main Wazirabad Road Bhajanpura, Delhi-110053

Copy:-

The Dy. Director of Education,
B-Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

4/20

1. Name & address of the building : Canterbury Model Public School, at B-46/10A
Main Wazirabad Road Bhajanpura, Delhi-53
2. Building is comprised of : Ground Plus three upper floors
(Porta cabin sealed on terrace)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2021/NDZ/1096 dt 31/12/2021
6. Fire Safety direction letter No : NBC part IV/BBL
7. Date of Inspection : 13/02/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Sh. Neeraj Gupta
10. Year of Construction : Before 2000
11. Applicant's letter No : Nil Dated- 18/12/2024

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV/BBL Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mtr. N/A N/A	15mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	02 nos. N/A	02 nos. N/A.	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	1.50mtr. N/A	1.50 mtr& 1.53 mtr. N/A.	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	Provided	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 nos. ABC /CO ₂ ISI marked	12 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-aid-Hose Reels.			
	• Total numbers on each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm	450Lpm	MR
	• Head of the Pump	40 mtr.	40 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr.	10,000ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note:- The Management has been submitted undertaking that the porta cabin constructed on terrace is not being used for school and any purpose and has been sealed by management.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter no. F.6/DFS/MS/School/2021/NDZ/1096 dated 31/12/2021 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Deepak 13/02/2025
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

DO(ED) *[Signature]* 13/02/2025

Sy. CFO/NDZ *[Signature]* 14/02/2025

C.F.O. *[Signature]* 14/2/2025

Director *[Signature]* 14/02/25

[Signature] 14/2/25

Sir, Pt. letter is put up for your kind signature pl.

Director *[Signature]*

Deepak 17/02/2025