

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2025/SZ/ 173

Dated: 17.04.2025

To

The Executive Engineer (Electrical)
Central Public Works Department,
CAPFIMS, PED, Rooms No 208,
Vidyut Bhawan, New Delhi 110001.
Email ID eeecapfimsped@gmail.com

Sub: Regarding issuance of FSC in r/o M/s Central Armed Police Force Institution of Medical Science (CAPFIMS) at Maidan Garhi New Delhi.

Sir,

This has reference to your online Fire NOC Dated 24/03/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.04.2025 in the presence of Mr. Pranjal Shrivastava (Executive Engineer/Civil) & Mr. Anup Kumar (Executive Engineer/ Electrical) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The plans of multilevel car parking I & 2 neither submitted by the CPWD for approval nor any fire safety guidelines were issued by this department.
2. As per the plans approved by this department the Utility block was comprised of G+1 floors whereas the block is now comprised of G+2 Floor, hence, there is a structural changes in the Utility block vis a vis constructed & approval vide letter of even no 279 dated 08.11.2016. Moreover only one staircase is provided against 02 staircases of 1.5 mtr each from ground to upper floors.
3. The auditorium block is comprised of ground and 1 upper floors and the observations noticed are as under:-
 - A. There are total four exits available against the requirement of 6 exits. The width of all doors varies in between 1.80 mtr - 1.85mtrs against the requirement of clear-cut width of 2.00 mtrs wide.
 - B. Rows of seats aisles shall have not more than 14 seats. Rows of seats opening to an aisle at one end only shall have not more than 7 seats.
 - C. Clear aisles not less than 1.2m in width shall be formed at right angles to the line of seating. The cross aisles shall be provided for every 10 rows.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE