

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2025/BP/ 253

Dated : 25/06/2025

To,

The Chief Architect,
Central Public Works Department,
Room No. 217-218, A-Wing, Nirman Bhawan
New Delhi.

Subject: Regarding clearance of building plans in r/o construction of Part Blocks (MLCP-1, MLCP-2 & Utility Building) at Central Armed Police Force Institute of Medical Sciences (CAPFIMS).

Sir,

Please refer your ID No. ADG PROJECT DELHIREGION 20250422/2394 dated 16.05.2025 on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed:

1. All around 09 meter motorable road with 12 m turning radius for fire tender movement is not provided as per clause 8.2 of UBBL 2016.
2. Fire control room is not proposed as per clause 9.3.10 of UBBL 2016.
3. Entry to the lift lobby is not through fire check door as per clause 8.4.5 of UBBL 2016.
4. The fire and life safety arrangements as per NBC part 4 / UBBL 2016 are not proposed.

Accordingly the case cannot be examined and therefore rejected.

Yours faithfully


26/6/2025
(Virendra Singh)
Chief Fire Officer
011 23412225
e 5