

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Mixed/2026/Outer-North/354

Dated: 10 / 08 / 2026

To,
The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, JLN Marg,
Minto Road, New Delhi-110002.

Sub: Application for grant of fire safety certificate in r/o **M/s Carnival A Unit of S R Motel Resorts located at 66/16/17/24/25, GT Road, Alipur, Delhi - 110036. (New Block).**

Sir,

This has a reference to online ID- 2026071009689 Dtd. 10/07/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officers concerned of this department on 25/07/2026 in the presence of Mr. Shiv Kumar, Owner. During course of inspection, the shortcomings observed are as below:-

1. Fire Check Door are not provided at some places.
2. No. of continuous staircase to terrace not provided as per requirement.
3. Carbon Monoxide detectors have not been provided as required under clause 7.31 of UBBL-2016 for Delhi.
4. Automatic Sprinkler system is not provided in banquets.
5. Main pump and stand by pump of 2280 lpm capacity with 40m head is not provided.
6. Jockey pump of 180 lpm capacity with 40m head is not provided.
7. Draw-off connection and Fire service inlet is not provided.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for absence of further action in the matter. The occupancy of the building/premises shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service