



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/SZ/GH/2025/272

Dated: 03/06/2025

To

The Joint Commissioner of Police,
Licensing Unit, 1st Floor Police Station,
Defence Colony
New Delhi.

Sub: - Inspection report in R/o Central Guest House, located at 4 & 5, Mehla Park Road, West Nizamuddin, New Delhi-110002

Sir,

Please refer to your online application letter No. 2025050307761 dated 03.05.2025 on the subject cited above. In this connection, it is to inform you that this department has already issued shortcoming vide letter No. F/6/DFS/MS/GH/SZ/2024/106 dated 20.03.2024 & F6/DFS/MS/GH/SZ/2024/552 dated 04.09.2024, has still not complied.


In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully


(VIRENDRA SINGH)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Owner/Occupier, Central Guest House, located at 4 & 5, Mehla Park Road, West Nizamuddin, New Delhi-110002. Online ID No. 2025050307761 dated 03.05.2025.


03/6/25



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI

NATIONAL CAPITAL TERRITORY OF DELHI
DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव
4102

No. F6/DFS/MS/GH/SZ/2024/106

Dated: 20/03/2024

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Central Guest House, Bldg no. -4 & 5, Mahila Park Road, Basti Hazrat Nizamuddin (West), New Delhi- 13.

Sir,

With reference to the MHA online application no. 2024022602162 dated 26.02.2024 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 06.03.2024 in the presence of manager and it was observed that following shortcomings were observed:

1. No alternate exit is available to the occupants of building no. 5. Same may be arranged by linking both the building at all floor levels.
2. Alternate exit of building no. 4 shall not be occupied by shops/combustibles.
3. The main staircase of both the buildings are not linked to terrace same shall be arranged.
4. Room on terrace shall be removed/demolished.
5. Hose reel/downcomer system at 1st floor shall be placed inside the building. Its present location is inaccessible.
6. Ventilation arrangements in the common areas shall be made in building no. 5.
7. Electrical meters & panels shall be relocated away from the staircase.
8. Entry/exits to the building shall be made free from parking.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

07/3/24