

C/136



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2025/SZ/ 428
To

Dated: 02/09/2025

Mr. Satyajit Roy
Scientist-C General Section,
Central Soil and Materials Research Station,
Olof Palme Marg, Hauz Khas, New Delhi 110016.

Sub: Regarding issuance of FSC in r/o M/s Central Soil and Materials Research Station,
Olof Palme Marg, Hauz Khas, New Delhi 110016.

Sir,

This has reference with your letter No-O-14012/1/2025-US(GEN)/1855 dated 01/08/2025 received through outdoor diary no 4668 dated 08/08/2025 on the subject cited above. In this connection, it is to inform you that the above said premise has been inspected by officer concerned of this department on 19.08.2025 in the presence of Mr. Salinder & Mr. Satyajit Roy to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. There are two staircases having width of 1.50 mtr & 1.10 mtr against the required width of 1.50 mtr & 1.25 mtr respectively.
2. Fire check door not provided at staircases & lift lobbies.
3. Sealing of shift not provided.
4. First aid hose reel hose found non- functional.
5. Automatic fire detection system found non-functional.
6. MOEFA not working.
7. Public address system not provided.
8. Internal hydrant found non-functional.
9. Electrical Fire Pump capacity 2400 LPM, Diesel Engine Pump 2400 LPM and Jockey Pump 280 LPM found non- functional.
10. Underground tank capacity 2,00,000 ltrs found empty.
11. Overhead tank capacity 25,000 ltrs not provided.
12. Exit signage not provided at strategical locations.

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE


Copy to: -

1. The Executive Engineer (Bldg.) Electric Constn. Division-VI, CPWD, Pushpa Bhawan, New Delhi 110062