

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Educational/2025/SZ/ 591

Dated: 04/12/2025

To.

✓ Sh. Anubhav Singh, Dy. Director (Admin.),
Centre for Cultural Resources and Training (CCRT),
Plot No. 15/A, Sector- 7, Dwarka, New Delhi – 110075.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Centre for Cultural Resources and Training located at Plot 15/A, Sector- 7, Dwarka, New Delhi – 110075.

Sir,

This has reference to your letter No. CCRT/11013/11/2018/8566 dated 17.09.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department visited the premises/building on dated 26.11.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Mahvir, AE (CPWD), was present and it was observed that the building is comprised of small basement, ground plus two upper floors, and following shortcomings were observed: -

1. First aid hose reels system provided but nozzle found removed at some places.
2. Pumps provided as per requirements but found not functional in auto mode.
3. Exit Sign's found removed at some places.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter.

Yours faithfully



(A.K. Malik)

Dy. Chief Fire Officer
South Zone

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Civic Centre, Minto Road, New Delhi.