



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 639

Dated: 11/08/2025

To

The Manager,  
Century Public School,  
Opp. Ambedkar Colony,  
Bijwasan, New Delhi-110061

**Sub: Renewal of Fire Safety Certificate in r/o Century Public School, Opp. Ambedkar Colony, Bijwasan, New Delhi-110061 (School ID: 1821182)**

Sir,

This has a reference to your letter No. CPS/2025/06/1613 dated 06/06/2025, received in this department vide outdoor diary No. 2573 dated 09/06/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 18/07/2025 from fire safety point of view, in the presence of Sh. Manish Dagar (LDC). During course of inspection, **the shortcomings observed are as below.**

1. The hose-reel hose found non-functional.
2. Terrace level fire pump was not on auto mode.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

*Virendra Singh*  
4/8/2025

(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.