



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/Hospital/2025/NDZ/ 51

Dated: 30/01/2025

FIRE SAFETY CERTIFICATE

Certified that the Chacha Nehru Bal Chikitsalaya located at Geeta Colony, Delhi - 110031, comprised of Basement + Ground plus five upper floors, owned/occupied by Chacha Nehru Bal Chikitsalaya, was issued FSC vide letter No. F6/DFS/Hospital/2022/NDZ/244 dated 02.06.2022. The Hospital building was re-inspected by the team of officers concerned of this department on 24/01/2025 in the presence of Mrs. Bhawana Sahu, XEN (E) & Mr. Manish Kumar, A.E (E) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Institutional" (Group-"C") with effect from 30/01/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on.....30/01/2025.....at New Delhi by.

ATUL KARG
DIRECTOR

DELHI FIRE SERVICE

To,

1. The Assistant Engineer (E) HE-3, HMED (East), PWD, GTB Hospital, Shahadara, Delhi
2. The Director, CNBC, Geeta Colony
3. The Executive Engineer (E), HMED (east), GTB Hospital Complex, Shahdara, Delhi
4. Junior Engineer (E), HE-3, HMED (East), CNBC, Geeta Colony

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Chacha Nehru Bal Chikitsalaya,
Geeta Colony, Delhi - 110031.
2. Building is comprised of : Basement + Ground plus five upper floors
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/Hospital/2022/NDZ/244 dated 02.06.2022
6. Fire Safety directive letter No : F6/DFS/MS/BP/Hos./2001/111 dated 15.01.2001
7. Date of Inspection : 24/01/2025
8. Name of the Inspecting officers : DO, A.K. Jaiswal & Deepak Kumar, ADO (LN.)
9. Name and designation of officer from the building side : Mrs. Bhawana Sahu, XEN (E) &
Mr. Manish Kumar, A.E (E)
10. Year of construction : 2005
11. Applicant's letter No : 10(7)AE(E)HE-3/PWD/GTB/2024-25/035
dated 16/01/2025

| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R33 | NBC Part IV Requirements | Provided at Site | Remarks MR/NMR |
|---------|--|--------------------------|------------------------|----------------|
| 01 | Access to Building. | | | MR |
| | • Road width | 06 mtrs. | 15 mtrs. | MR |
| | • Gate width | 4.5 mtrs. | 6.0 mtrs. | MR |
| | • Width of internal road | 6.0 mtrs. | 6.0 mtrs. | MR |
| 02 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | 06 nos. | 06 nos. + Ramp | MR |
| | • Upper floor | 05 nos. | 05 nos. + Ramp | MR |
| | • Basement | | | |
| | B. Width of Staircases | 2.00 mtrs. | 6 x 1.5 m & Ramp 2.5 m | MR (old Case) |
| | • Upper floor | 2.00 mtrs. | 6 x 1.5 m & Ramp 5 m | MR (old Case) |
| | • Basement | | | |
| | c. Protection of Exits | Required | Provided | MR |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | 02 nos. | 02 nos. | MR |
| | d. No. of Continuous Staircases to Terrace | 2.40 mtrs. | 2.50 & 3.0 mtrs. | MR |
| | e. Width of Corridor | 1.50 mtrs. | 2.0 & 1.0 mtrs. | MR |
| | f. Door Size | | | |
| 03 | Compartmentation. | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire rating of shaft door | Required | Provided | MR |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers | Required | Provided | MR |
| 04 | Smoke Management System. | | | |
| | • Basement | 30 a/c per hour | Provided | MR |
| | • Upper floor | 12 a/c per hour | Provided | MR |
| 05. | Fire Extinguishers. | | | |
| | • Total numbers | 60 nos. | 80 nos. | MR |
| | • Types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

2A


| | | | | |
|----|--|-------------------|----------|-----|
| 06 | First-Aid-Hose Reels. | | | |
| | • Total numbers on each floor | 06 nos. | 06 nos. | MR |
| | • Length of hose reel hose | 30 mtrs. | 30 mtrs. | MR |
| | • Nozzle diameter | 05 mm | 05 mm | MR |
| 07 | Automatic Fire Detection and Alarming System. | | | |
| | • Type of detectors | Smoke & Heat | Provided | MR |
| | • Location of main panel | Control Room | Provided | MR |
| | • Location of repeater panel | N/A | Provided | MR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooter's location | Required | Provided | MR |
| 08 | MOEFA | Required | Provided | MR |
| 09 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | Required | Provided | MR |
| | • Upper floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | Required | Provided | MR |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100 mm | 100 mm | MR |
| | • Number of hydrants per floor | 06 nos. | 06 nos. | MR |
| | • Hose box | 06 nos. | 06 nos. | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | 06 nos. | 06 nos. | MR |
| | • Hose box | 06 nos. | 06 nos. | MR |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | | | |
| | • Discharge of main pump | 2850 LPM | 2850 LPM | MR |
| | • Head of main pump | 60 mtrs. | 60 mtrs. | MR |
| | • Number of main pumps | 03 no. | 03 no. | MR |
| | • Jockey pump out put | 180 LPM | 180 LPM | MR |
| | • Jockey pump head | 60 mtrs. | 60 mtrs. | MR |
| | • Standby pump out put | 2850 LPM | 2850 LPM | MR |
| | • Standby pump head | 60 mtrs. | 60 mtrs. | MR |
| | • Auto starting /manual stopping | Auto Starting | Provided | MR |
| | • Pump house access | Required | Provided | MR |
| | ➤ Terrace Level | | | |
| | • Discharge of pump | N/A | N/A | N/A |
| | • Head of the pump | N/A | N/A | N/A |
| | • Power supply | N/A | N/A | N/A |
| | • Auto starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | 2, 00,000 liters. | Provided | MR |
| | • Draw-off connection | Required | Provided | MR |
| | • Fire service inlet | Required | Provided | MR |
| | • Access to tank | Required | Provided | MR |
| | • Overhead tank capacity | 30,000 Liters. | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |

N/35.

| | | | | |
|----|---|----------|----------|-----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of lift shaft | Required | Provided | MR |
| | • Pressurization of lift lobby | Required | Provided | MR |
| | • Communication in lift car | Required | Provided | MR |
| | • Firemen's grounding switch | Required | Provided | MR |
| | • Lift signage | Required | Provided | MR |
| 17 | Standby Power Supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | Required | Provided | MR |
| | • Flow switch panel | Required | Provided | MR |
| | • PA system panel | Required | Provided | MR |
| | • Battery backup | Required | Provided | MR |
| | • Building floor plans | Required | Provided | MR |
| 20 | Special Fire Protection systems for protection of special Risks, if Any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcoming issue vide letter no. F.6/DFS/MS/Hospital/NDZ/2024/334 dated 15/06/2024 has been rectified now.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter no. F6/DFS/Hospital/2022/NDZ/244 dated 02.06.2022 renewal under 35 of the Delhi Fire Service rules 2010, is recommended.



 24/01/2025
 Signature of the Inspecting Officer
 Name :- Deepak Kumar
 Designation :- ADO (Shah.)

~~DO (E.D.)~~


 24/01/2025

Dy. CFO (NDZ) on leave

CFO


 24/01/2025

Director



Sir. pt. letter is put up for your kind signature pl.


 28/01/2025

Director

