



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/184

Dated: 22/04/2025

To

The President,
Chandra Bhushan Singh Memorial Mahila, Bal
Evam Shravan Viklang Shiksha Evam Punarvas Sansthan at PSP
Sector-13, Dwarka,
New Delhi-110078

Sub: Renewal of Fire Safety Certificate in r/o Chandra Bhushan Singh Memorial Mahila, Bal
Evam Shravan Viklang Shiksha Evam Punarvas Sansthan at Sector-13, (Near Iskcon
Temple), Dwarka, New Delhi-110078

Sir,

This has reference to your application (Form 'J') dated 20/03/2025, received through outdoor diary No. 14800 dated 21/03/2025 on the subject cited above. In this connection, it is to inform you that the above said premise was visited by the officer concerned of this department on 09/04/2025 in the presence of Sh. Hitesh Singh (Ex. Manager) to verify the availability and operability of fire safety measures. During the course of inspection, the shortcomings observed are as below.

1. Sprinkler system needs to be extended in left out area in basement.
2. Fire pumps at ground & terrace level not found automatic in operation.
3. Overhead water storage exclusively for firefighting found used for domestic purpose.
4. Exit signage & lift signage found removed at some locations.
5. Basement floor found used for school activities. Same shall be got checked and approved from the authority concerned.

In view of above, application for renewal of fire safety certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter. The occupancy of the building in the absence of valid Fire Safety Certificate shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054