



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

C 34





No 6 / DFS / MS / 2025 / School / WZ / 1162

Dated 18/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Chaudhary Chhoturam Memorial Public School located at Bhagat Singh Park, Siraspur, Delhi-110042 comprised of 02 Blocks (Ground and First floor) owned/ occupied by Chaudhary Chhoturam Memorial Public School have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. 3298-3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on 29.08.2025 in the presence of Sh. Jai Bhagwan Rana (Manager) and found that the building/ premises is fit for occupancy Group B Educational with effect from 18/09/2025 for a period of 03 (Three) years subject to compliance of the conditions mentioned below:

Issued on .....18/09/2025 at New Delhi by

  
(Virendra Singh)  
Chief Fire Officer  


Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. Principal, Chaudhary Chhoturam Memorial Public School, located at Bhagat Singh Park, Siraspur, Delhi-110042.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

**INSPECTION REPORT**

1. Name & address of the building : Chaudhary Chhoturam Memorial Public School, located at Bhagat Singh Park, Siraspur, Delhi-110042.
2. Type of Occupancy : Educational
3. Building Comprised of : Previous 03 Blocks- (01 BL- G+1 & 02 BL- GF only).  
Now 02 Blocks (Ground and first floor)
4. Type of Case : New (Addition/ Alteration)
5. Details of Previous NOC : F6/DFS/MS/2018/1304 dated 05/06/2018
6. Fire Safety directives letter No : Director of education circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 29/08/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Jai Bhagwan Rana (Manager)
10. Year of Construction : 1996 & 2014
11. Applicant's letter No. : Outdoor Diary No. 4732 dated 11/08/2025

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | DOE Requirement                       | Provided at site     | Remarks MR/NMR |
|--------|---|---------------------------------------|----------------------|----------------|
| 1.     | <b>Access to building</b>                                   |                                       |                      |                |
|        | Road width  | 6 m                                   | Provided             | MR             |
|        | Gate width  | 4.5 m                                 | Directly Accessible  | MR             |
|        | Width of internal road                                      | NA                                    | NA                   | NA             |
| 2.     | <b>Number, Width, Type &amp; Arrangement of Exits</b>       |                                       |                      |                |
|        | Number of staircases  |                                       |                      |                |
|        | Upper Floors  | 02 in each block                      | Provided             | MR             |
|        | Basements   | NA                                    | NA                   | NA             |
|        | Width of staircases   |                                       |                      |                |
|        | Upper Floor   | 1.5 m each                            | Provided             | MR             |
|        | Basements   | NA                                    | NA                   | NA             |
|        | Protection of exits   |                                       |                      |                |
|        | Fire check door   | NA                                    | NA                   | NA             |
|        | Pressurization  | NA                                    | NA                   | NA             |
|        | No. of continuous staircases to terrace                     | NA                                    | NA                   | NA             |
|        | Width of Corridor   | NA                                    | NA                   | NA             |
|        | Door Size   | Old Block - 1 m<br>New Block - 1.20 m | Provided             | MR             |
| 3.     | <b>Compartmentation</b>                                     |                                       |                      |                |
|        | Fire check door   | NA                                    | NA                   | NA             |
|        | Sealing of electrical shafts                                | NA                                    | NA                   | NA             |
|        | Fire Rating of shaft door                                   | NA                                    | NA                   | NA             |
|        | Water Curtain   | NA                                    | NA                   | NA             |
|        | Fire Dampers  | NA                                    | NA                   | NA             |
| 4.     | <b>Smoke Management System</b>                              |                                       |                      |                |
|        | Basements   | NA                                    | NA                   | NA             |
|        | Upper floors  | Required                              | Naturally Ventilated | MR             |
| 5.     | <b>Fire Extinguishers</b>                                   |                                       |                      |                |
|        | Total numbers   | 12                                    | Provided             | MR             |
|        | Types   | ABC Type                              | Provided             | MR             |
|        | IS marking  | Required                              | Provided             | MR             |
| 6.     | <b>First-Aid Hose Reels</b>                                 |                                       |                      |                |
|        | Total numbers on each floor                                 | NA                                    | NA                   | NA             |
|        | Length of hose reel hose                                    | NA                                    | NA                   | NA             |
|        | Nozzle diameter   | NA                                    | NA                   | NA             |
| 7.     | <b>Automatic fire detection and alarming system</b>         |                                       |                      |                |
|        | Type of detectors   | NA                                    | NA                   | NA             |
|        | Location of Main Panel                                      | NA                                    | NA                   | NA             |



|     |   |          |          |    |
|-----|---|----------|----------|----|
|     | Location of Repeater Panel              | NA       | NA       | NA |
|     | Alternate source of power               | NA       | NA       | NA |
|     | Hooters' Location                       | NA       | NA       | NA |
| 8.  | MOEFA                                   | NA       | NA       | NA |
| 9.  | Public Address System                   | NA       | NA       | NA |
| 10. | Automatic Sprinkler System              |          |          |    |
|     | Basement                                | NA       | NA       | NA |
|     | Ground Floor                            | NA       | NA       | NA |
|     | Sprinkler above false ceiling           | NA       | NA       | NA |
| 11. | Internal Hydrants                       |          |          |    |
|     | Size of riser/down-comer                | NA       | NA       | NA |
|     | Number of hydrants per floor            | NA       | NA       | NA |
|     | Hose Box                                | NA       | NA       | NA |
| 12. | Yard Hydrants                           |          |          |    |
|     | Total number of hydrants                | NA       | NA       | NA |
|     | Hose Box                                | NA       | NA       | NA |
| 13. | Pumping Arrangements                    |          |          |    |
|     | Ground Level                            |          |          |    |
|     | Discharge of main Pump                  | NA       | NA       | NA |
|     | Head of Main pump                       | NA       | NA       | NA |
|     | Number of main pumps                    | NA       | NA       | NA |
|     | Jockey Pump out put                     | NA       | NA       | NA |
|     | Jockey pump head                        | NA       | NA       | NA |
|     | Standby Pump out put                    | NA       | NA       | NA |
|     | Standby Pump Head                       | NA       | NA       | NA |
|     | Auto Starting/Manual Stopping           | NA       | NA       | NA |
|     | Pump House Access                       | NA       | NA       | NA |
|     | Terrace level                           |          |          |    |
|     | Discharge of pump                       | NA       | NA       | NA |
|     | Head of the pump                        | NA       | NA       | NA |
|     | Power Supply                            | NA       | NA       | NA |
|     | Auto Starting of pump                   | NA       | NA       | NA |
| 14. | Captive Water Storage for fire fighting |          |          |    |
|     | Underground tank capacity               | NA       | NA       | NA |
|     | Draw-off connection                     | NA       | NA       | NA |
|     | Fire service inlet                      | NA       | NA       | NA |
|     | Access to tank                          | NA       | NA       | NA |
|     | Overhead Tank capacity                  | NA       | NA       | NA |
| 15. | Exit Signage.                           | Required | Provided | MR |
| 16. | Provision of Lifts.                     |          |          |    |
|     | Pressurization of Lift Shaft            | NA       | NA       | NA |
|     | Pressurization of Lift lobby            | NA       | NA       | NA |
|     | Communication In lift Car               | NA       | NA       | NA |
|     | Fireman's Grounding Switch              | NA       | NA       | NA |
|     | Lift Signage                            | NA       | NA       | NA |
| 17. | Standby power supply                    | NA       | NA       | NA |
| 18. | Refuge Area.                            |          |          | NA |

|   |    |    |    |
|---|----|----|----|
| Migration   | NA | NA | NA |
| Fire Control Room   |    |    |    |
| Detector System Panel   | NA | NA | NA |
| Flow Switch Panel   | NA | NA | NA |
| PA System Panel   | NA | NA | NA |
| Battery backup  | NA | NA | NA |
| Building Floor Plans  | NA | NA | NA |
| Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/School/2023/WZ/514 dated 25/10/2023.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular dated 01/03/2011, it is **recommended to grant Fire Safety Certificate.**

*(Signature)*  
1/9/24

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

*Do (B.W.) Promoted as Dy Cfo*

*Director*

*(Signature)*  
8/2/24

*CFO*  
*(Signature)*  
6/9/2025

*Principal Director*

*CFO to Genl.*

*(Signature)*  
12/5/25

*CFO*

*ADD (B.W.)*

*(Signature)*  
15/9/2025

*Gr. IT letter in reply to principal*

*(Signature)*  
17/9/25

*CFO*  
*(Signature)*  
8/9/2025

*me*

*CCFO-428 MB*  
*Dated 2/9/2025*