

C/67

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/FH/205/SZ/ 359

Dated: 31/07/2025

To

The Chinderella Farm House,  
Kh. No. 662/1, 662/2,  
Village Chatterpur, Tehsil Mehrauli,  
New Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o The Chinderella Farm House,  
located at Kh. No. 662/1, 662/2, Village Chatterpur, Tehsil Mehrauli, New Delhi

Sir,

This has reference to with letter no nil dated nil received through outdoor diary no 3149 dated 26/06/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 11.07.2025 in the presence of Mr. Ankit Kumar (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The First Aid Hose reel provided but found non-functional.
2. MOEFA not working.
3. The Internal Hydrant provided but found non-functional.
4. Fire Fighting pumps capacity 450 LPM provided but found non-functional.
5. Overhead tank capacity 3000 ltrs provided against the required capacity 10,000 ltrs.
6. Exit signage found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



**(VIRENDRA SINGH)**  
**CHIEF FIRE OFFICER**  
**DELHI FIRE SERVICE**

