



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-69
75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/ 669

Dated: - 10/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Chopra International Guest House, 4058-4060, Gali Kaseruwalan, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026061308822 dated 13/06/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 18/06/2026 in the presence of Mr. Intesar Alam, Manager and following shortcomings were observed: -

1. Automatic operation of Fire Pump found removed.
2. Domestic connection provided in Overhead water storage tank is not permitted.

Further, undertaking regarding usage of 4th & 5th floors of the building is required to submitted.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

o/c Bf

Copy to: -

1. The Manager, M/s Chopra International Guest House, 4058-4060, Gali Kaseruwalan, Paharganj, New Delhi - 110055.