



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/SZ/EH/2025/ 651

Dated: 31 / 12 / 2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s VIP RDX Restro & Bar (A U/o Solitaire Good Food Hospitality), AB-4, GF & Mezzanine Floor, Community Centre, Safdarjung Enclave, New Delhi - 110029.

Sir,

Please refer to online application No. 2025120215349 dated 02/12/2025 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 05/12/2025 in the presence of Sh. Anand Kumar, Purchase Manager and following shortcomings were observed: -

1. Out of 03 nos. staircases, only one staircase having width of 94 cms. was shown in the premise, whereas one staircase was found locked and one staircase was found removed.
2. Overhead water storage tank and fire pump could not be checked as the staircase serving up to terrace level was locked.
3. Hose reel was found removed.
4. Internal hydrants including Hose boxes were found removed.
5. Manually Operated Electrical Fire Alarm (MOEFA) provided but found non-functional.
6. Exit signages found removed.
7. Sprinklers provided but found non-functional.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stand **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Proprietor, M/s VIP RDX Restro & Bar (A U/o Solitaire Good Food Hospitality), AB-4, GF & Mezzanine Floor, Community Centre, Safdarjung Enclave, New Delhi - 110029.