



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आज़ादी का  
अमृत महोत्सव 647

No. F6/DFS/MS/NDZ/2025/ 25

Dated: 14/01/2025

To,

The Authorized Signatory,  
M/s Cipla at M2 A & M1 B,  
J.R Complex No. 5, HCMR Farms,  
Village Mandoli, Delhi - 110093.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Cipla located at M2 A & M1 B,  
J.R Complex No.5, HCMR Farms, Village, Mandoli, Delhi - 110093.**

Sir,

This has a reference to your Email dated 12/12/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 20/12/2024 in the presence of Mr. Rajender Sharma (Manager) to view the fire safety measures provided in the ground, mezzanine and one upper floor. During course of inspection, following shortcomings were observed.

1. One staircase of width 1.5 meters provided against requirement of 02 nos. of staircase width of 1.5 meters.
2. Smoke management is not provided sufficiently.
3. Sprinkler system is not provided in entire building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg), Municipal Corporation of Delhi, Plot No. 419, Patparganj Industrial Area, Delhi -110092 :- to kindly verify the use of building as storage.