

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/2025/ School/ 921

Dated: 24/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Vishwa Bharti Public School, at Plot No 1, Sector-6, Dwarka, New Delhi. comprises of Basement, Ground + 04 upper floors, was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/2024/1156 Dated 03/12/2024 for the composition of basement, ground and three upper floor. Now, the school building was jointly re- inspected by the officers concerned of this department on 12/07/25 in the presence of the Mr. Jatin, Mr. Virendra Aggarwal & Mr. Surya Pratap Sharma (JE), Mr. Madhuban Bhai Patel (AE) and found that school has complied with the fire prevention and fire safety requirements in accordance with circular of Director of education dated 17/01/2005 and the premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I (B+G+04 upper floors)** with effect from ..... 24/07/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ..... 24/07/2025 ..... at New Delhi by.

  
 24/07/2025  
 (Virendra Singh)  
 Chief Fire Officer  
 Delhi Fire Service

**Copy to:-**

1. The Dy. Director (land and building), DDA , Vikas Sadan, INA, New Delhi: Online application no. DW6/0185/202-OCC dated 01.07.2025
2. Director of Education, Govt. of NCT, of Delhi.
3. The Manager, Vishwa Bharti Public School, at Plot No 1, Sector-6, Dwarka, New Delhi.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. Basement shall be used for storage as per BBL Concerned.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited.

~110

### INSPECTION REPORT

1	Name & Address of the Building	M/s Vishwa Bharti Public School, at Plot No 1, Sector-6, Dwarka, New Delhi.		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, Ground plus 04 Upper Floors		
4	Type of Case	Addition/ alteration		
5	Details of Previous NOC	F6/DFS/MS/School/2024/1156 Dated 03/12/2024 for Basement, Ground plus three upper floors.		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/96/1071 Dated 04/09/1996 F6/DFS/BP/2022/School/26 dated 24/01/2022		
7	Date of Inspection	11-07-2025		
8	Name of the Inspecting Officers	Sh. Ravinder Singh ADO/CC& Sh. Rajinder Atwal , DO/CD		
9	Name & Designation of Officers from the building side	Mr. Virendra Aggarwal & Mr. Surya Pratap Sharma (JE), Mr. Madhuban Bhai Patel (AE)		
10	Year of construction	2003 & 2025		
11	Applicant letter No	Online id DW6/0185/2021 OCC dated 01/07/2025		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	60 mtr	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	6 mtr	Provided	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	06 No's	Provided	MR
	➤ Basement floor.	02 No's	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr each	Provided	MR
	➤ Basement floor	1.50 mtr each	Provided	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization /naturally	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.2 mtr at 4 <sup>th</sup> floor	1.2 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	12 ACPH	Exhaust fan Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	35 nos	35 Nos	MR
	• Types	ABC	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR

6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	04 nos	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	100mm	100 mm	MR
	• Number of Hydrant per floor	04 nos	Provided	MR
	• Hose box.	04 nos	Provided	MR
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	2280 LPM	Provided	MR
	➤ Head of main pump.	70 m	Provided	MR
	➤ Number of main pumps.	01	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	70 m	Provided	MR
	➤ Standby Pump output.	2280 LPM	Provided	MR
	➤ Standby Pump head.	70 m	Provided	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	2,00,000 Ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	25,000 ltrs	25,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17.	<b>Standby Power Supply</b>	Required	Provided (DG Set)	MR

2/12

18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel (MCP)	Required	Provided	MR
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	Required	Provided	MR
	• Battery backup.	Required	Provided	MR
	• Building floor plan.	Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

The FSC issued earlier for basement, ground and three upper floors vide letter no. F6/DFS/MS/School/2024/1156 Dated 03/12/2024 shall stand null and void.

In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may issue the FSC as per DFS Act and Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name :- Rajinder Atwal  
Designation :- DO (CD)

Name :- Ravinder Singh  
Designation :- ADO (CC)

CFD/

21/11/2025

Principal Director

950 May 2025

CFD/

22/11/2025

ADO (CC)

As approved, FT is put up for kind perusal and signature.

CFD/ 24/11/2025

MS Cell

23/11/25