

C-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 232

Dated: 23/05/2025

To,

The Manager  
M/S PLAY, Shop No. TF 01,  
City Square Mall, Plot No. 7, 8,  
Shivaji Place, District Centre,  
Raja Garden, Delhi-110027.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S PLAY, Shop No. TF 01, City Square Mall, Plot No. 7, 8, Shivaji Place, District Centre, Raja Garden, Delhi-110027.**

Sir,

This has reference to online 2025042306972 dated 23.04.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 21/05/25 in the presence of Sh. Mahesh , Manager and following shortcomings were observed at the time of inspection:-

1. Pumps, hose reels, hydrants, detection system, MCP, PA system, Sprinklers found nonfunctional.
2. Exit signage's found removed.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

1. The Joint commissioner of Police ( Lic.) First floor, PS Defence Colony New Delhi.