



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-56
28/07/2025

No:F.6/DFS/MS/GH/2025/NDZ/ 327

Dated: 28/07/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s City View Guest House located at 2152, Gali No. 1 & 2, Chuna Mandi, Pahar Ganj, Delhi 110055.

Sir,

This has reference to online application received through MCD portal vide ID- 2025063010727 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 17/07/2025 to see the compliance of requisite fire safety measures. Sh. Ashok Garg was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. First aid hose reels found provided but not functional.
2. Carbon monoxide detectors found not functional at some places.
3. Terrace level pump not found in auto mode.
4. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

28/7/2025

(Virendra Singh)
Chief Fire Officer

ou R

Copy to:-

1. The owner/ occupier, M/s City View Guest House located at 2152, Gali No. 1 & 2, Chuna Mandi, Pahar Ganj, Delhi- 110055.
2. MCD Portal ID No. 2025063010727.