

CFR

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/CGHS/2025/SZ/318

Dated: 02/07/2025

To

The President/Secretary,
Vivekanand CGHS Ltd,
Plot No. 2, Sector-5,
Dwarka, New Delhi-110075

Sub: Regarding issuance of Fire Safety Certificate in r/o Vivekanand CGHS Ltd located at Plot No. 2, Sector-5, Dwarka New Delhi.

Sir,

This has a reference to your letter No. Nil dated 01.06.2025 received in this department vide outdoor diary No. 2411 dated 04.06.2025, on the subject above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 21/06/2025 in the presence of Mr. Saurabh Sisodia (Acting President) to verify the availability and operability of fire protections measures. During course of inspection, the shortcomings observed are as below.

1. Smoke exhaust system & automatic sprinkler system in basement found non-functional.
2. First aid hose reel system found non-functional.
3. Manually operated electrical fire alarm system found non-functional.
4. Internal hydrants found non-functional and some hose-boxes empty.
5. Terrace level fire pump found non-functional.

In view of the above, issuance of fire safety certificate is rejected. You are advised to rectify the above shortcomings at your earliest under intimation to this department in the interest of public safety.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Dy. Director (L&I), Building Section, Delhi Development Authority, Vikas Sadan, INA, New Delhi.