

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2025/School/WZ/ 1063

Dated 25/08/2025

FIRE SAFETY CERTIFICATE

Certified that the CL. Indian Public School located at Kh. No. 251, Main Road, Holambi Khurd, Delhi-110082 comprised of Ground plus First floor was issued FSC by this department vide letter No F6/DFS/MS/2022/School/WZ/902 dated 18.08.2022. The premises was re-inspected by the officer concerned of this department on 12.08.2025 in the presence of Sh. Jawahar Singh Mann (Chairman), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy (Group B) Educational with effect from25.1.98.12.23. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 25/08/2025 at New Delhi by

(Virendra Singh) Chief Fire Officer

He N

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054

2. The Principal, CL. Indian Public School located at Kh. No. 251, Main Road, Holambi Khurd, Delhi-110082.

Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.

3. The trained fire fighting staff should be available round the clock.

4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.

5. This certificate cannot be treated in any case for regularizations of unauthorized construction.

6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building: CL. Indian Public School located at Kh. No. 251, Main Road, Holambi

Khurd, Delhi- 110082.

2. Type of Occupancy

: Educational

3. Building Comprised of 4. Type of Case

: Ground and First Floor. Renewal

5. Details of Previous NOC

F6/DFS/MS/2022/School/WZ/902 Dated- 18/08/2022

6. Fire Safety directives letter No :

DOE Circular Dated 01/03/2011

7. Date of inspection

12/08/2025

8. Name of Inspecting Officer 9. Name and designation of officers

R.K.Sinha, ADO (BW)

From the building side 10. Year of Construction

Sh. Jawahar Singh Mann (Chairman)

11. Applicant's letter No

S.	11. Applicant's letter No. : Minimum Standards on fire	Outdoor Diary No. 43: DOE circular Date		Remarks			
No.	prevention and fire safety U/R 33	01/03/2011	u Provided at site	MR/NMR			
	Access to building	01/03/2011					
	Road width	6 m	Provided	MR			
	Gate width	4.5 m	Directly Accessible	MR			
	 Width of internal road 	NA	NA	NA			
2.	Number, Width, Type & Arrangen						
	a. Number of staircases		N				
	Upper Floors	02	02	MR			
	Basements	NA	NA	NA			
	b. Width of staircases						
	Upper Floor	1.50 m each	1.27 m & 1.80 m	MR (old case)			
	Basements	NA	NA	NA			
	c. Protection of exits		M M				
	Fire check door	NA	NA	NA			
	Pressurization	NA	NA	NA			
	d. No. of continuous staircases to terrace	NA	NA	NA			
	(Maria Maria Maria)	NA	NA	NA ·			
	e. Width of Corridor	200	Provided	MR			
	f. Door Size	1 m	Provided	MIX			
3.	Compartmentation						
.	Fire check door	NA	NA	NA			
		NA	NA	NA			
	Sealing of electrical shafts	NA	NA	NA			
	Fire Rating of shaft door	NA NA	NA NA	NA			
	Water Curtain	NA NA	NA	NA			
	• Fire Dampers NA NA NA Smoke Management System						
4.	(B000-0-2-0-3)	NA	NA	NA			
	Basements			(50-6309)			
	 Upper floors 	Required	Naturally Ventilated	MR			
5.	Fire Extinguishers	04 Nos.	10 Nos.	100			
	Total numbers			MR			
	• Types	ABC/ Co2 Type	Provided	MR			
	IS marking Peole	Required	Provided	MR			
i	• Total numbers on each floor	NA	NA				
	7 1 (1 1 1	NA NA	NA NA	NA			
-	In the second	NA NA	1,34000.00	NA			
	Nozzle diameter	IM	NA	NA			
	Automatic fire detection and alarming system						
•	Type of detectors	NA	NA				
}	Location of Main Panel	NA		NA			
-	Location of Repeater Panel	NA NA	NA	NA			
	Alternate source of power	NA NA	NA	NA			
	•		NA	NA			
	 Hooters' Location 	NA	NA	₩0.20.50V			
		0/	INA	NA			

	MOFFA	A I A	***			
	MOEFA	NA	NA	NA Y		
	Public Address System	NA	NA	NA P		
10.	Automatic Sprinkler System					
	Basement	NA	NA	NA.		
	Ground Floor	NA	NA NA	NA NA		
	Sprinkler above false ceiling	NA	NA	NA		
11.	Internal Hydrants		233.0	1		
	 Size of riser/down-comer 	NA	NA	NA		
	Number of hydrants per floor	NA	NA	NA		
,,	Hose Box	NA	NA	NA		
12.	Yard Hydrants					
	Total number of hydrants	NA	NA	N/A		
	Hose Box	NA	NA NA	NA NA		
13.	Pumping Arrangements		177	INA		
-	· Country I					
-	Ground Level Discharge of main Pump	NIA				
		NA NA	NA NA	NA		
	➤ Head of Main pump	NA	NA	NA		
	Number of main pumps	NA	NA	NA		
ŀ	Jockey Pump out put	NA	NA	NA		
-	> Jockey pump head > Standby Pump out put	NA	NA	NA		
-	Standby Pump out putStandby Pump Head	NA	NA	NA		
F	> Auto Starting/Manual	NA NA	NA	NA		
	Stopping	NA	NA	NA		
	➤ Pump House Access	NA	NA	NA		
	Terrace level					
	 Discharge of pump 	NA	NA			
Γ	➤ Head of the pump	NA	NA NA	NA NA		
-	3) 7			NA		
-	➤ Power Supply ➤ Auto Starting of pump	NA	NA	. NA		
14.	Auto Starting of pump NA NA Captive Water Storage for fire fighting			NA		
	Underground tank capacity	NA	274			
-	> Draw-off connection	NA NA	NA	NA		
	Fire service inlet	NA NA	NA	NA		
	> Access to tank	NA NA	NA NA	NA		
	Overhead Tank capacity	NA	NA NA	NA		
15.	Exit Signage.	Required	Provided	NA MR		
16.	Provision of Lifts.					
	Pressurization of Lift Shaft	NA	NA	NA		
	Pressurization of Lift lobby	NA	NA NA	NA NA		
	Communication In lift Car	NA	NA NA	NA NA		
	Fireman's Grounding Switch	NA	NA	NA		
	Lift Signage	NA	NA ·	NA		
17.	Standby power supply	NA	NA	NA NA		
18.	Refuge Area.					
-	➤ Total Area ➤ Location	NA NA	NA NA	NA		
19. I	Fire Control Room	IVA	NA	NA		
	A CONTRACTOR OF THE CONTRACTOR					
	Detector System Panel	NA	NA	NA		

g

Flow Switch Panel PA System Panel	NA	NA	T
	NA		NA
	NA		NA
Fire Production	NA		NA
tion of special Disks is	NA		NA
or special Risks, if any:		IVA	NA
	PA System Panel Battery backup Building Floor Plans Il Fire Protection System for etion of special Risks, if any:	PA System Panel NA Battery backup NA Building Floor Plans NA NA I Fire Protection System 6	PA System Panel NA NA NA Battery backup NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular dated 01/03/2011, it is recommended to 18/08/2022.

Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

Principal Director

CFO to Ser.

950

/hul 20181 2015

2018/12018 Der. [-T latter - Puto-fr

pototo son pleo

cfo(obs)

1 201 201x

M