



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No: F.6/DFS/MS/EH//2025/WZ/303

Dated: 04/07/2025

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> Floor,  
Police Station, Defence Colony,  
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Clue Lounge & Bar (A Unit of Westernside Food Matrix Pvt. Ltd.) located at 27, 3<sup>rd</sup> Floor, NWA Club Road, West Punjabi Bagh, New Delhi- 110026.

Sir,

This has reference to online application received through MCD portal vide ID- 2025051208349, on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 25.06.2025 in presence of Mr. Ranjan Mishra, Manager. Following shortcoming were observed at the time of inspection.

1. First aid hose reel found provided but not functional.
2. Detectors found provided but not functional.
3. MOEFA found provided but not functional.
4. Pumping system found provided but not functional.
5. Terrace level tank of 30,000 ltrs capacity found provided against the requirement of 50,000 ltrs.
6. Exit signage's found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. The owner/ occupier, M/s Clue Lounge & Bar. (A Unit of Westernside Food Matrix Pvt. Ltd.) located at 27, 3<sup>rd</sup> Floor, NWA, Club Road, West Punjabi Bagh, New Delhi- 110026.
2. MCD Portal ID No. 2025051208349.