



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

4/20  
16/09/2025

No.F.6/DFS/MS/CNG/2025/NDZ/ 460

Dated: 16/09/2025

To,

The Authorized Signatory,  
Young Optimistic Transport Solution Pvt. Ltd.  
75, 3<sup>rd</sup> Floor, Vijay Block, Vikas Marg, Laxmi Nagar,  
Delhi-110092

**Subject:-Application for Fire NOC Certificate for Yamuna Vihar DTC CNG Bus Depot.**


Sir,

This is in reference to your letter no. YOT/25-26/223 dated 06/08/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the premises on dated 30/08/2025 in presence of Sh. Ajay Kumar, Manager. Following shortcomings were observed during the time of inspection.

1. MOEFA is not provided.
2. Terrace pump 450 lpm head 40 meters is not provided.
3. An overhead tank 10,000 liters not provided.

Keeping In view of the above, Fire Safety Certificate cannot be considered at this stage. You are requested to apply again after compliance of above-mentioned shortcomings for further consideration in this matter.

Yours faithfully,

  
16/09/2025  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER

ok 2