

C-89

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F-6/ DFS/MS/2026/CNG/WZ/03

Dated 06.01.2026

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Filling Station (IGL) located at Kh. No. 31/25 (4-6), Village Safipur Ranhola, Nangloi, New Delhi- 110041 comprised of Ground floor only owned/ occupied by Indraprastha Gas Limited have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 24/12/2024 in the presence of Sh. Kundan (Operator) and that the building/premise is fit for occupancy (Hazardous) "CNG Filling Station Group 'J' with effect from 06.01.2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 06.01.2026 at New Delhi by

  
(S.K. Dua)  
Dy. Chief Fire Officer (WZ)  
Delhi Fire Service  


Copy to :-

1. Chief General Manager (CNG Projects), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) at Kh. No. 31/25 (4-6), Village Safipur Ranhola, Nangloi, New Delhi-110041.

2. Type of Occupancy : CNG Filling station Group 'J'

3. Building Comprised : Ground Floor only.

4. Type of Case : New Case

5. Details of previous NOC : Nil

6. Fire Safety directives letter No : F6/DFS/MS/BP/2023/274 Dated 08/08/2023

7. Date of inspection : 24/12/2025

8. Name of the Inspecting Officers : R.K. Sinha, ADO (Jawala Puri)

9. Name and designation of officers from the building side : Sh. Kundan (Operator)

9. Year of Construction : ---

10. Applicant's letter No. : Email ID dated 15.12.2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA

5	<b>Fire Extinguishers</b>			
6	<b>First-Aid Hose Reels.</b>	• Total numbers	15 nos	18 nos
		• Types	ABC & Co2	05 trolley- 75 kg. each, 08- DCP & 05-Co2
		• ISI marking	Yes	Yes
7	<b>Automatic fire detection and alarming system</b>			
8	<b>MOEFA</b>	• Type of detectors	Gas & Flame detector	Provided
		• Location of Main Panel	Ground Floor	Provided
		• Location of Repeater Panel	NA	NA
		• Alternate source of power	Required in Panel	Provided
		• Hooters' Location	Ground Floor	Provided
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
11	<b>Internal Hydrants</b>	• Basement	NA	NA
		• Upper Floor	NA	NA
		• Sprinkler above false ceiling	NA	NA
12	<b>Yard Hydrants.</b>			
13	<b>Pumping Arrangements.</b>	• Total number of hydrants	NA	NA
		• Hose Box	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>	• Ground Level	N/A	N/A
		➢ Discharge of main Pump	N/A	N/A
		➢ Head of Main pump	N/A	N/A
		➢ Number of main pumps	N/A	N/A
		➢ Jockey Pump out put	N/A	N/A
		➢ Jockey pump head	N/A	N/A
		➢ Standby Pump out put	N/A	N/A
		➢ Standby Pump Head	N/A	N/A
		➢ Auto Starting/ Manual stopping	N/A	N/A
		➢ Pump House Access	N/A	N/A
		• Terrace level	N/A	N/A
		➢ Discharge of pump	N/A	N/A
		➢ Head of the pump	NA	NA
		➢ Power Supply	NA	NA
		➢ Auto Starting of pump	NA	NA
		• Underground tank capacity	NA	NA

	➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity	NA NA NA NA	NA NA NA NA	NA NA NA NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts. • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage	N/A N/A NA NA NA	N/A N/A NA NA NA	N/A N/A NA NA NA
17	Standby power supply	NA	NA	NA
18	Refuge Area. ➤ Total Area ➤ Location	N/A N/A	N/A N/A	N/A N/A
19	Fire Control Room • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring in premises & Co2 flooding system, gas cascade protected with water mist, 02 Hand held explosive meter	Provided	MR

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection. The management had rectified that shortcomings issued vide letter no. F6/DFS/MS/CNG/2025/WZ/607 Dated 12/12/2025.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to Grant Fire Safety Certificate under Rule 35 of Delhi Fire Service Rules 2010.

*Ado/JWP  
26/12/25*  
Signature of the Inspecting Officer  
Name: - Rajeev Kumar Sinha  
Designation- ADO/JWP

*Do (WSP) M 31/12*

*Dr (F.S./C.S.)*

*Pr. Director*

*LIVE  
31/12/25*

*My. Cfo to Jswm.*

*02/01/26*

*F.T. Please.*

*LIVE*

*05/01/26*

*ADO (JWP)*

*Dr. F.P. meter in Pre for Ssw/M*

*LIVE  
06/01/26*

*Dr (F.S./C.S.)*

*F.P. wing*

*Qd  
ADO (JWP)  
6/1/2026*