

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/CNG/WZ/ 56

Dated: 03/02/25

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) at CNG Filling Station (IGL) , Sector-19, Delhi, comprised of **Ground floor only** owned / occupied by **Indraprastha Gas Limited** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/CNG/WZ/87** dated **28.02.2022**. The premises was re-inspected by the officer concerned of this department on **22.01.2025** in the presence of **Sh. Puneet (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class '**Hazardous (Group-J)**' with effect from 03/02/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/02/2025 at New Delhi by

(Atul Garg)
DIRECTOR
 Ph: 011-23414000

Copy to :-

1. Sh. Ajay Khatri (DGM (Fire & Safety) IGL Bhawan Plot No.4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
 s/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/) http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) at CNG Filling Station (IGL) , Sector-19, Rohini, Delhi-86.
2. Type of Occupancy : Group J Hazardous Building (Ground Floor Only)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2022/CNG/WZ/87 dated 28.02.2022.
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 22.01.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Puneet (Manager)
9. Year of Construction :
10. Applicant's letter No. : OD No.10921 dated 30.12.2024.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1,	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible NA NA	30m NA NA	MR NA NA
2,	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3,	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4,	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	NA NA	NA NA
5,	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	29nos. ABC/CO2/DCP ISI marked	Provided 75kg-07 18-DCP & 04-Co2 Yes	MR MR MR
6,	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7,	Automatic fire detection and alarming system			


New

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA		NA
8.	MOEFA	Required	Provided		MR
9.	Public Address System	NA	NA		NA
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
11.	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA		NA
		NA	NA		NA
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
14.	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
15.	Exit Signage.	NA	NA		NA
16.	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
17.	Standby power supply	NA	NA		NA
18.	Refuge Area.				



	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Fire buckets filled with sand, no smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen premises & Co2 flooding system found provided.		MR


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2022/CNG/WZ/87 dated 28.02.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO (Rohini)



DO (N/W)


 24/01/2025

 24/01/2025


 27/1/2025


DCFO/948-N/W

Dated 27.01.25


 28/01/2025
 Director

 28/1/25



A letter is put up
 for kind perusal and
 Signature please.


 20/1/25