

C/33



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/CNG/WZ/2025/ 444

Dated: 21/08/2025



FIRE SAFETY CERTIFICATE

Certified that the **CNG Filling Facilities at Site No-6, Community Centre, Sector-16, Rohini Delhi**, comprised of **Single Story Building** owned/ occupied by **Indraprastha Gas Limited** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **29.07.2025** in the presence of **Mr. Arun Sharma (Manager)** and that the building/ premise is fit for occupancy **Hazardous (Group-J)** with effect from 21/08/2025 for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 21/08/2025 at New Delhi by

21/08/2025
 (Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Sh. Pulkit Bhardawaj, AGM (CNG Projects) IGL Bhawan Plot No.4, Community Centre, R. K. Puram, Sector-9, New Delhi-110022.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
 s/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/)

INSPECTION REPORT

1. Name & address of the building : CNG Filling Facilities at Site No-6, Community Centre, Sector-16, Rohini, Delhi-
2. Type of Occupancy : Group J Hazardous Building
3. Type of Case : New Case (Single Story Building)
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : F.6/DFS/MS/CNG/BP/2023/304 dated 13.09.2023.
6. Date of inspection : 29.07.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Arun Sharma (Manager)
9. Year of Construction : 2025
10. Applicant's letter No. : OD No-1163 dated 29.04.2025.


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	30m	Provided	MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible -NA-	Directly accessible -NA-	MR -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper Floors Basements 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of staircases	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper Floor Basements 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits	-NA-	-NA-	-NA-
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- Required -NA- -NA- -NA-	-NA- provided -NA- -NA- -NA-	-NA- MR -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	75kg-05 10kg-15 4.5kg-04CO2 ABC/CO2/DCP ISI marked	Provided Provided Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level	-NA-	-NA-	-NA-
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	-NA-	-NA-	-NA-
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply			
		-NA-	-NA-	-NA-

18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	Fire buckets filled with sand, no smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen premises & Co2 flooding system found provided, fire mix trolley		MR

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is **recommended to grant Fire Safety Certificate** under rule 35 of the Delhi Fire Service Rule 2010.


 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO (Rohini)



DO (N/W)
 DCFO/04-NW/...
 Dated...05/08/25


 04/02/2025
 By Cfo (102)


 5/8


 14/8/2025

Principal Director Cfo to Gen.


 ADO (Rohini)
 Cfo
 18/8/2025
 Fi letter is put up for kind
 perusal and signature please

 18/8/25