



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001




No F 6 / DFS / MS / 2025 / CNG/WZ/ 459

Dated 03/09/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Dispensing Station (IGL) located at Kh. No. 29/19 Min (6 Bigha, 00 Biswa), Village Chandpur, Kanjhawala, Delhi-110081 comprised of Ground floor only owned/occupied by Indraprastha Gas Limited was issued FSC by this department vide letter No F6 /DFS/MS/2022/CNG/304 dated 11.07.2022. The premise was re-inspected by the officer concerned of this department on 20.08.2025 in the presence of Mr. Amit (Manager) and observed that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy "CNG Filling Station Group J" with effect from 03/09/2025 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/09/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The G.M. (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : CNG Dispensing Station (IGL) located at Kh. No. 29/19 Min (6 Bigha 00 Biswa), Village Chandpur, Kanjhawala, Delhi-110081.
2. Type of Occupancy : CNG Filling Station, **Group J**
3. Building Comprised of : Ground floor only
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2022/CNG/304 dated 11/07/2022
6. Fire Safety directives letter No : F6/DFS/MS/CNG/2020/590 dated 21/02/2020
7. Date of inspection : 20/08/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Mr. Amit (Manager)
10. Year of Construction : 2022
11. Applicant's letter No. : Outdoor Diary No. 4392 dated -1/08/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part -IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	8 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10	Provided	MR
	• Types	ABC, CO2 & Water Mist com foam trolley	02 Trolley 75 kg each, 06 DCP, 03 – CO2 & 01- Water mist cum foam trolley	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	Gas & Flame	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

275

	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

Fire Control Room

	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Fire buckets filled with sand, No Smoking boards in Hindi and English, No loose electric wiring seen & Co2 flooding system, 02 Hand held explosive meters	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is **recommended to renew** the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/CNG/304 dated 11/07/2022 under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

DDFO-328 NW
Date: 26/8/25

DO (G/W)

25/08/2025

By cfo (102)

26/8

CFO

27/8/2025

Principal director

CFO to Jm.

28/58/25

CFO

29/8

ADO (102)

Sr. Ft. Jm. 29/8

1/9/25

29/8/2025 MS